

**DEPARTMENT OF TRANSPORTATION - District 4 Toll Bridge Program**

333 Burma Rd.  
Oakland, CA 94607  
(510) 622-5660, (510) 286-0550 fax



*Flex your power  
Be energy efficient!*

June 13, 2008

Contract No. 04-0120F4  
04-SF-80-13.2 / 13.9  
Self-Anchored Suspension Bridge  
Letter No. 05.03.01-002178

Michael Flowers  
Project Executive  
American Bridge/Fluor, A JV  
375 Burma Road  
Oakland, CA 94607

Dear Michael Flowers,

**Submittal 94, Rev. 2 - Fabrication Procedure - T1 Tower Lift Erection Splice Mock-Up**

The Department has completed review of Submittal ABF-SUB-00094R02, "Fabrication Procedure - T1 Tower Lift Erection Splice Mock-Up," dated June 10, 2008. The submittal is "Approved." Please be aware of the following comments:

**CATEGORY B:**

1. ZPMC is required to perform work to validate the use of jacks to correct the cross-sectional misalignment per ABF-ZPM-LTR-000155, authored by ABF, dated May 27, 2008. This plan must be addressed in future submittals.
2. Plans to survey the chord length of the top and bottom shafts of the 114m mock-up (at the centerline of the splice) after the mock-up is disassembled will be addressed in future submittals. The survey data shall be compared to that taken before the first unapproved jacking operation to verify that the shafts were not deformed inelastically due to the jacking operations.

If you have any questions, please contact Gary Lai at the working drawing campus.

Sincerely,

A handwritten signature in blue ink, appearing to read "G. Pursell".

GARY PURSELL  
Resident Engineer

cc: Rick Morrow  
Mark Woods  
file: 05.03.01, 55.0094