

**DEPARTMENT OF TRANSPORTATION -Toll Bridge Program**

333 Burma Rd.

Oakland, CA 94607

(510) 622-5660, (510) 286-0550 fax

*Flex your power  
Be energy efficient!*

January 05, 2010

Contract No. 04-0120F4

04-SF-80-13.2 / 13.9

Self-Anchored Suspension Bridge

Letter No. 05.03.01-006273

Michael Flowers  
Project Executive  
American Bridge/Fluor, A JV  
375 Burma Road  
Oakland, CA 94607

Dear Michael Flowers,

**Submittal 1389, Rev. 1 – MFSQA for Zhang Jiagang Rong Chang (ZJRC)**

The Department has completed review of Submittal ABF-SUB-001389R01, "Manufacturing and Fabrication Self Qualification Audit (MFSQA) for Zhang Jiagang Rong Chang Hot Dip Galvanizing Co., Ltd," dated December 21, 2009. ZJRC Hot-Dip Galvanizing Co., Ltd is a subcontractor to ZPMC. The submittal is "Rejected" as outlined by the comments below.

The Contractor should consider scheduling a meeting with the Department's representatives based at ZPMC to clarify the requirements under Section 8-4, "Audits" of the Contract Special Provisions. The Contractor is not permitted to schedule an audit until all comments have been addressed and the MFSQA approved.

**CATEGORY A:**

1. Provide all sections of the MFSQA that are relevant to the galvanizing process, which includes Sections A, D, F, G, J, K and L and qualify the response to these MFSQA questions by referencing all specific sections of the Galvanizing and/or QC Manual.
2. Provide the galvanizing procedures that Zhang Jiang Rong Chang Hot Dip Galvanizing Co., Ltd (ZJRC) will use in performing the work on the Project. Please note that not only is the provided procedure a verbatim copy of that provided by ZPMC in Submittal ABF-SUB-000907R01, but the "Repairing Procedure" clearly states that it belongs to ZPMC.
3. Provide ZJRC's Quality Manual/Procedures, along with any supporting quality documentation to demonstrate that the company is capable of performing galvanizing to meet all of the contract requirements.
4. Provide the resume (work experience) of the Quality Control Manager, Mr. Gou Haijun.
5. Provide the names and job functions of the QC inspectors. Provide their details in the Organization Chart.

6. Provide samples of the QC forms that will be used by ZJRC.

If you have any questions, please contact Mohammad Fatemi at (916) 813-3677

Sincerely,



GARY PURSELL  
Resident Engineer

cc: Rick Morrow; Brian Boal; Gary Lai; Mark Woods; Mohammad Fatemi; Mazen Wahbeh  
file: 05.03.01, 55.1389