

APPENDIX



D



November 4, 1998

job #2848.98

Mr. Kevin Brown
GEOCON
11375 Sunrise Park Drive, Suite 100
Rancho Cordova, CA 95742

REF: Asbestos Survey results for the:

**San Francisco Bay Bridge
Administration Building
and
Warehouse/Maintenance
Building**

Dear Mr. Brown:

Per your request, HB&T Environmental, Inc. undertook an Asbestos Survey at the above referenced location on October 6, 1998. The purpose of this survey was to ascertain the existence of any Asbestos-Containing Building Materials (ACBMs) that may be in the area prior to any planned demolition activities.

During the course of the survey a total of 171 (one hundred and seventy one) bulk samples were taken of suspect ACBMs. All samples taken were catalogued on site and were then delivered to Western Analytical Laboratory for analysis by Polarized Light Microscopy. The subsequent analysis of these samples showed Asbestos present in 50 (fifty) of the samples. (See included laboratory report #4014)

Listed by location and sample number in the following tables is the relevant information for each Asbestos-containing sample noted in the laboratory report.

