

**DEPARTMENT OF TRANSPORTATION**

DIVISION OF ENGINEERING SERVICES

OFFICE ENGINEER

1727 30<sup>th</sup> Street MS-43

P.O. BOX 168041

SACRAMENTO, CA 95816-8041

FAX (916) 227-6214

www.dot.ca.gov/hq/esc/oe



*Serious Drought.  
Help save water!*

April 15, 2015

01-Men-101-48  
01-262064  
Project ID 0115000012  
ACNHP-Q101(266)E

Addendum No. 3

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ADJACENT TO THE STATE HIGHWAY IN MENDOCINO COUNTY NEAR WILLITS AT ASSESSOR'S PARCEL NUMBER 108-030-05-00.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Tuesday, April 28, 2015.

This addendum is being issued to revise the project plans, the *Notice to Bidders and Special Provisions*, and the *Information Handout*.

Project plan sheet 9 is replaced and attached for substitution for the like-numbered sheet.

In the Special Provisions, Section 2-1.06B, the following is added to the table under description:

"Wetland Inundation Boundaries."

In the Special Provisions, Section 6-2.03, the table is replaced as follows:

"The Department furnishes you with:

Seed Item	Quantity	Dates Available
Acorn (Group O-M)	As Required	October 1, 2016
Erosion Control Seed	As Required	September 1, 2015
Plant Propagation Seed	Refer to section 20-7.03A	September 1, 2015

"

In the Special Provisions, Section 8-1.04C is replaced as attached.

In the Special Provisions, Section 20-1.03C(1), "General," the second paragraph is revised as follows:

"Control rodents by using traps."

01-Men-101-48  
01-262064  
Project ID 0115000012  
ACNHP-Q101(266)E

In the Special Provisions, Section 20-3.01B(2)(a), "Plants," is added as follows:

"Plants must be the variety and size shown and true to the type or name shown. Plants must be individually tagged or tagged in groups identifying the plants by species or variety. Tagging is not required for cuttings.

Plants must be healthy, well-formed, not root-bound, free from insect pests and disease, and grown in nurseries inspected by the Department of Food and Agriculture.

The plants must comply with the size and type shown in the following table:

Plant group designation	Description	Container size (cu in)
A	No. 1 container	152–251
B	No. 5 container	785–1242
C	Balled and burlapped	--
E	Bulb	--
F	In flats	--
H	Cutting	--
I	Pot	--
K	24-inch box	5775–6861
M, M-M	Liner <sup>a</sup>	24
O	Acorn	--
P	Plugs <sup>a, b</sup>	--
S	Seedling <sup>c</sup>	--
U	No. 15 container	2768–3696

"

In the Special Provisions, Section 20-3.03C(1), "General," is replaced as follows:

"Stake wetland inundation boundaries under Chapter 6 A.8 of the Department's Survey Manual. Stake at 5 foot horizontal intervals or as directed by the Engineer. Allow 5 days for the Engineer to review approve the staking. Do not start work until the Engineer has inspected and approved the delineated boundaries."

In the Special Provisions, Section 20-4.03D, "Invasive Plant and Weed Control," the fourth paragraph is revised as follows:

"Control invasive plants and weeds as ordered by:

1. Hand pulling:
  - 1.1. Within 2 feet of any woody plant
2. Mowing:
  - 2.1. The mowing limit must be 2 feet beyond all woody plants"

"The *Information Handout* "Water Inundation Boundaries" is added as attached.

Addendum No. 3  
Page 3  
April 15, 2015

01-Men-101-48  
01-262064  
Project ID 0115000012  
ACNHP-Q101(266)E

To *Bid* book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the *Notice to Bidders* section of the *Notice to Bidders and Special Provisions*.

Submit the *Bid* book as described in the *Electronic Bidding Guide* at the Bidders' Exchange website.

**[http://www.dot.ca.gov/hq/esc/oe/electronic\\_bidding/electronic\\_bidding.html](http://www.dot.ca.gov/hq/esc/oe/electronic_bidding/electronic_bidding.html)**


Inform subcontractors and suppliers as necessary.

This addendum, EBS addendum file and attachments are available for the Contractors' download on the Web site:

**[http://www.dot.ca.gov/hq/esc/oe/project\\_ads\\_addenda/01/01-262064](http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/01/01-262064)**

If you are not a *Bid* book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

  
For CHARLIE FIELDER  
District Director

Attachments

**Replace "Reserved" in section 8-1.04C with:**

Section 8-1.04B does not apply.

Start job site activities within 55 days after receiving notice that the Contract has been approved by the Attorney General or the attorney appointed and authorized to represent the Department.

Do not start job site activities until the Department authorizes or accepts your submittal for:

1. CPM baseline schedule
2. WPCP or SWPPP, whichever applies
3. Weed Management Plan
4. Access and staging plans
5. Plant delivery schedule

You may enter the job site only to measure controlling field dimensions and locate utilities.

Do not start other job site activities until all the submittals from the above list are authorized or accepted and the following information is received by the Engineer:

1. *Notice of Materials To Be Used* form.
2. Written statement from the vendor that the order for plant (Group M), plant (Group M-M) has been received and accepted by the vendor. The statement must show the dates that the materials will be shipped.

You may start job site activities before the 55th day after Contract approval if you:

1. Obtain specified authorization or acceptance for each submittal before the 55th day
2. Receive authorization to start

Submit a notice 72 hours before starting job site activities. If the project has more than 1 location of work, submit a separate notice for each location.