

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

OFFICE ENGINEER

1727 30th Street MS-43

P.O. BOX 168041

SACRAMENTO, CA 95816-8041

FAX (916) 227-6214

www.dot.ca.gov/hq/esc/oe



*Serious Drought.
Help save water!*

June 18, 2014

04-Ala-5785

04-014104

Project ID 0413000133

Addendum No. 3

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN ALAMEDA COUNTY IN OAKLAND AT THE SAN FRANCISCO-OAKLAND BAY BRIDGE MAINTENANCE YARD.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Tuesday, June 24, 2014.

This addendum is being issued to revise the *Notice to Bidders and Special Provisions*.

In the Special Provisions, Section 16722A(3), "System Description," sub-section "Design Requirements," the following paragraph is added after the last paragraph:

"The existing fire alarm control system is Siemens Desigo, Model #FC2025."

In the Special Provisions, Section 16724A(3), "System Description," sub-section "Design Requirements," the following paragraphs are added after the last paragraph:

"The existing intrusion alarm system is Bosch, Model #D9412GV4.

The existing access control system is RS2 Technology, Model #EP-1502."

In the Special Provisions, Section 16726A(3), "System Description," sub-section "Design Requirements," the following paragraph is added after the last paragraph:

"The existing CCTV System is Bosch DIVAR IP 7000."

Addendum No. 3
Page 2
June 18, 2014

04-Ala-5785
04-014104
Project ID 0413000133

To *Bid* book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the *Notice to Bidders* section of the *Notice to Bidders and Special Provisions*.

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the *Bid* book.

Submit bids in the *Bid* book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This addendum is available for the Contractors' download on the Web site:

http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/04/04-014104

If you are not a *Bid* book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,



for MOHSEN SULTAN
Chief, Office of Plans, Specifications & Estimates
Office Engineer
Division of Engineering Services