

DEPARTMENT OF TRANSPORTATION
DIVISION OF ENGINEERING SERVICES
 OFFICE ENGINEER, MS 43
 1727 30TH STREET
 P.O. BOX 168041
 SACRAMENTO, CA 95816-8041
 FAX (916) 227-6214
 TTY (916) 227-8454



*Flex your power!
 Be energy efficient!*

**** WARNING ** WARNING ** WARNING ** WARNING ****
This document is intended for informational purposes only.

Users are cautioned that California Department of Transportation (Department) does not assume any liability or responsibility based on these electronic files or for any defective or incomplete copying, excerpting, scanning, faxing or downloading of the contract documents. As always, for the official paper versions of the bidders packages and non-bidder packages, including addenda write to the California Department of Transportation, Plans and Bid Documents, Room 0200, P.O. Box 942874, Sacramento, CA 94272-0001, telephone (916) 654-4490 or fax (916) 654-7028. Office hours are 7:30 a.m. to 4:15 p.m. When ordering bidder or non-bidder packages it is important that you include a telephone number and fax number, P.O. Box and street address so that you can receive addenda.

April 24, 2006

04-CC,Mrn-580-10.0/12.5,0.0/3.1
 04-041524

Addendum No. 2

Dear Contractor:

This addendum is being issued to the contract for construction on State highway in CONTRA COSTA AND MARIN COUNTIES ON ROUTE 580 RICHMOND-SAN RAFAEL BRIDGE.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on May 16, 2006 instead of the original date of April 26, 2006.

This addendum is being issued to set a new bid opening date as shown herein, revise the Project Plans, the Notice to Contractors and Special Provisions and the Proposal and Contract.

Project Plan Sheet 51, under "QUANTITIES," the quantities for Rapid Setting Concrete (Patch) and Furnish Polyester Concrete Overlay are revised as follows:

"RAPID SETTING CONCRETE (PATCH)	50 M3
FURNISH POLYESTER CONCRETE OVERLAY	1900 M3"

In the Special Provisions, Section 10-1.21, "EXISTING HIGHWAY FACILITIES," subsection "REMOVE UNSOUND CONCRETE," the sixth paragraph is replaced as follows:

"Voids created by the removal of unsound concrete to be patched with rapid setting concrete shall be patched prior to preparing the bridge deck for the polyester concrete overlay.

Voids created by the removal of unsound concrete to be filled with the polyester concrete shall be cleaned by abrasive blasting and shall be filled at the same time when placing polyester concrete overlay."

In the Special Provisions, Section 10-1.23, "POLYESTER CONCRETE OVERLAY," subsection "CONSTRUCTION," the following paragraphs are added after the first paragraph:

"Attention is directed to "Remove Unsound Concrete," regarding patching voids created by the removal of unsound concrete.

The thickness of polyester concrete overlay shown on the plans is the minimum thickness. The thickness will vary depending on the thickness of the bridge deck surface removed."

Addendum No. 2
Page 2
April 24, 2006

04-CC,Mrn-580-10.0/12.5,0.0/3.1
04-041524

In the Special Provisions, Section 10-1.23, "POLYESTER CONCRETE OVERLAY," subsection " MEASUREMENT AND PAYMENT," the third paragraph is revised as follows:

"The contract price paid per cubic meter for furnish polyester concrete overlay shall include full compensation for furnishing all labor, materials, tools, equipment, and incidentals, and for doing all the work involved in furnishing polyester concrete, including polyester resin binder, promoter/initiator, and aggregate, and filling the voids created by the removal of unsound concrete with polyester concrete, including abrasive blasting, as shown on the plans, as specified in the Standard Specifications and these special provisions, and as directed by the Engineer."

In the Proposal and Contract, the Engineer's Estimate, Items 17 and 18 are revised as attached.

To Proposal and Contract book holders:

Replace page 3 of the Engineer's Estimate in the Proposal with the attached revised page 3 of the Engineer's Estimate. The revised Engineer's Estimate is to be used in the bid.

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the NOTICE TO CONTRACTORS section of the Notice to Contractors and Special Provisions.

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the proposal.

Submit bids in the Proposal and Contract book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This office is sending this addendum by confirmed facsimile to all book holders to ensure that each receives it. A copy of this addendum is available for the contractor's use on the Internet Site:

http://www.dot.ca.gov/hq/esc/oe/weekly_ads/addendum_page.html

If you are not a Proposal and Contract book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

REBECCA D. HARNAGEL, Chief
Office of Plans, Specifications & Estimates
Office Engineer

Attachments

ENGINEER'S ESTIMATE

04-041524

Item No.	Item Code	Item Description	Unit of Measure	Estimated Quantity	Unit Price	Item Total
1	070012	PROGRESS SCHEDULE (CRITICAL PATH METHOD)	LS	LUMP SUM	LUMP SUM	
2	070018	TIME-RELATED OVERHEAD	LS	LUMP SUM	LUMP SUM	
3	074019	PREPARE STORM WATER POLLUTION PREVENTION PLAN	LS	LUMP SUM	LUMP SUM	
4	074020	WATER POLLUTION CONTROL	LS	LUMP SUM	LUMP SUM	
5	038703	TEMPORARY CONCRETE WASHOUT FACILITIES	LS	LUMP SUM	LUMP SUM	
6	074033	TEMPORARY CONSTRUCTION ENTRANCE	EA	2		
7	074041	STREET SWEEPING	LS	LUMP SUM	LUMP SUM	
8 (S)	120090	CONSTRUCTION AREA SIGNS	LS	LUMP SUM	LUMP SUM	
9 (S)	120100	TRAFFIC CONTROL SYSTEM	LS	LUMP SUM	LUMP SUM	
10 (S)	120159	TEMPORARY TRAFFIC STRIPE (PAINT)	M	80 000		
11 (S)	128650	PORTABLE CHANGEABLE MESSAGE SIGN	EA	15		
12	BLANK					
13	129100	TEMPORARY CRASH CUSHION MODULE	EA	34		
14 (S)	040229	REMOVE CEMENT MORTAR DECK SURFACE	M2	121 200		
15	153223	REMOVE UNSOUND CONCRETE	M3	159		
16	153225	PREPARE CONCRETE BRIDGE DECK SURFACE	M2	121 200		
17	511124	RAPID SETTING CONCRETE (PATCH)	M3	50		
18	515041	FURNISH POLYESTER CONCRETE OVERLAY	M3	1900		
19 (F)	515042	PLACE POLYESTER CONCRETE OVERLAY	M2	121 200		
20 (S)	840515	THERMOPLASTIC PAVEMENT MARKING	M2	940		