

**DEPARTMENT OF TRANSPORTATION**

ES-OE MS #43  
1727 30TH Street, 2ND Floor  
Sacramento, CA 95816



August 8, 2001

07-Ven-101-38.6/50.6  
07-192904  
ACSTPHG-P101(982)E

Addendum No. 3

Dear Contractor:

This addendum is being issued to the contract for construction on State highway in VENTURA COUNTY IN VENTURA FROM MONTALVO SPUR OVERHEAD TO WEST MAIN STREET UNDERCROSSING.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on August 23, 2001. The original bid opening date was previously postponed indefinitely under Addendum No. 2 dated July 26, 2001.

This addendum is being issued to set a new bid opening date as shown herein and to revise the Project Plans, the Notice to Contractors and Special Provisions, and the Federal Minimum Wages with Modification Number 7 dated 7-27-01. A copy of the modified wage rates are available for the contractor's use on the Internet Site:

**[http://www.dot.ca.gov/hq/esc/oe/weekly\\_ads/addendum\\_page.html](http://www.dot.ca.gov/hq/esc/oe/weekly_ads/addendum_page.html)**

Project Plan Sheets 39 and 78 are revised. Half-sized copies of the revised sheets are attached for substitution for the like-numbered sheets.

Project Plan Sheet 2, Note 3, is revised as follows:

"3. For Concrete Barrier (Type 60 Modified) with Scupper Opening, see Detail A and B on sheet C-1."

Project Plan Sheet 4, Note 4, is revised as follows:

"4. For Concrete Barrier (Type 60 Modified) with End Anchorage, see Detail A on sheet C-1."

In the Special Provisions, Section 10-1.25, "ASPHALT CONCRETE TYPE B (TEXTURED PAVING)," the sixth paragraph is deleted.

Addendum No. 3  
Page 2  
August 8, 2001

07-Ven-101-38.6/50.6  
07-192904  
ACSTPHG-P101(982)E

In the Special Provisions, Section 10-1.25, "ASPHALT CONCRETE TYPE B (TEXTURED PAVING)," the ninth paragraph is revised as follows:

"Asphalt concrete Type B (Textured Paving) shall be colored and scaled in a 2-step process in the following sequence:

Colored surface coating shall be evenly applied to asphalt concrete Type B (Textured Paving) and non-textured border areas when the asphalt concrete has cooled sufficiently per manufacturer's recommended application procedures. The coating shall be an integrally colored, polymer-modified cementitious coating and shall be applied a minimum of 0.7-mm thick. The color shall closely conform to Federal Standard Color #20059, Federal Standard Color #22144 or Federal Standard Color #35250 as shown on plan. The color coat shall be applied when the air temperature is above 7°C and precipitation is not expected within 24 hours.

Color coat hardener shall be diluted per the manufacturer's recommendations and evenly applied by a spray method after the color coat surface has dried. After spray application, the surface may be lightly broomed to ensure an even application. A second coat of hardener shall be applied after the first coat has dried."

To Proposal and Contract book holders:

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the proposal.

Submit bids in the Proposal and Contract book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This office is sending this addendum by UPS overnight mail to Proposal and Contract book holders to ensure that each receives it.

If you are not a Proposal and Contract book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

REBECCA D. HARNAGEL, Chief  
Plans, Specifications & Estimates Branch  
Office of Office Engineer

Attachment