

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

OFFICE ENGINEER

1727 30th Street MS-43

P.O. BOX 168041

SACRAMENTO, CA 95816-8041

FAX (916) 227-6214

www.dot.ca.gov/hq/esc/oe



*Serious Drought.
Help save water!*

February 18, 2015

08-Riv-10-R135.10

08-0L5904

Project ID 0800000421

Addendum No. 4

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN RIVERSIDE COUNTY ON ROUTE 10 ABOUT 17.5 MILES WEST OF BLYTHE AT WILEY'S WELL SAFETY ROADSIDE REST AREA.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Thursday, March 5, 2015.

This addendum is being issued to revise the project plans and the *Notice to Bidders and Special Provisions*.

Project plan sheets 13, 26, 27, 28, 30 and 32 are replaced and attached for substitution for the like-numbered sheets.

In the *Notice to Bidders*, the tenth paragraph is replaced as follows:

"Complete the work within 130 days."

In the Special Provisions, Section 99-11140B, "Materials," the first subparagraph of the second paragraph, "Duplex Pumps" is replaced as follows:

"Duplex pumps must be factory-assembled, multi-stage, centrifugal, submersible, and direct-connected (suitable for Class I, Division I and Division 2 applications). Casing must be corrosion resistant, stainless steel, 300 series with screened inlet, and vertical discharge for piping connection. Pump must have a start coil and run coil integrated in the motor."

In the Special Provisions, Section 99-11140B, "Materials" the first and second subparagraphs of the fourth paragraph, "Float Tree Assembly" are deleted.

In the Special Provisions, Section 99-16912B(1), "General," the fourteenth paragraph is replaced as follows:

"Seal Failure Relay, SFR: Seal failure relay is not required."

Addendum No. 4
Page 2
February 17, 2015

08-Riv-10-R135.10
08-0L5904
Project ID 0800000421

To *Bid* book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the *Notice to Bidders* section of the *Notice to Bidders and Special Provisions*.

Submit the *Bid* book as described in the *Electronic Bidding Guide* at the Bidders' Exchange website.

http://www.dot.ca.gov/hq/esc/oe/electronic_bidding/electronic_bidding.html

Inform subcontractors and suppliers as necessary.

This addendum, EBS addendum file and attachments available for the Contractors' download on the Web site:

http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/08/08-0L5904

If you are not a *Bid* book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,



for BASEM E. MUALLEM, P.E.
District Director

Attachments