

**DEPARTMENT OF TRANSPORTATION**  
DIVISION OF ENGINEERING SERVICES  
OFFICE ENGINEER

1727 30<sup>th</sup> Street MS-43  
P.O. BOX 168041  
SACRAMENTO, CA 95816-8041  
FAX (916) 227-6214  
[www.dot.ca.gov/hq/esc/oe](http://www.dot.ca.gov/hq/esc/oe)



*Serious Drought.  
Help save water!*

August 24, 2016

08-SBd-10, 60-6.2/9.2, R3.4/R4.6  
08-0R4804  
Project ID 0812000088  
ACNHPI-X071(068)E

Addendum No. 1

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN SAN BERNARDINO COUNTY, IN ONTARIO ON ROUTE 10 FROM 0.2 MILE EAST OF VINEYARD AVENUE OVERCROSSING TO 0.1 MILE EAST OF MILLIKEN AVENUE AND IN CHINO ON ROUTE 60 FROM 0.2 MILE WEST OF MOUNTAIN AVENUE UNDERCROSSING TO EUCLID AVENUE UNDERCROSSING to revise the *Notice to Bidders and Special Provisions*.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Tuesday, September 13, 2016.

In the Special Provisions, Section 86-1.01D(b)(3)(i) is added as attached.

Addendum No. 1  
Page 2  
August 24, 2016

08-SBd-10, 60-6.2/9.2, R3.4/R4.6  
08-0R4804  
Project ID 0812000088  
ACNHPI-X071(068)E

To *Bid* book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the *Notice to Bidders* section of the *Notice to Bidders and Special Provisions*.

Submit the *Bid* book as described in the *Electronic Bidding Guide* at the Bidders' Exchange website.

**[http://www.dot.ca.gov/hq/esc/oe/electronic\\_bidding/electronic\\_bidding.html](http://www.dot.ca.gov/hq/esc/oe/electronic_bidding/electronic_bidding.html)**

Inform subcontractors and suppliers as necessary.

This addendum, EBS addendum file and attachment are available for the Contractors' download on the Web site:

**[http://www.dot.ca.gov/hq/esc/oe/project\\_ads\\_addenda/08/08-0R4804](http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/08/08-0R4804)**

If you are not a *Bid* book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,



EDWARD ARMIJO  
Senior, AADD Coordinator  
Office Engineer  
Division of Engineering Services

Attachment

Replace the table in the RSS for section 86-1.01D(3)(b)(i) with:

**Nondestructive Testing for Steel Standards and Poles**

Weld location	Weld type	Minimum required NDT
Circumferential splices around the perimeter of tubular sections, poles, and arms	CJP groove weld with backing ring	100% UT or RT
Longitudinal seam	CJP or PJP groove weld	Random 25% MT
Longitudinal seam within 6 inches of a circumferential splice	CJP groove weld	100% UT or RT
Welds attaching base plates, flange plates, pole plates, or mast arm plates to poles or arm tubes	CJP groove weld with backing ring and reinforcing fillet	$t \geq 5/16$ inch: 100% UT and 100% MT $t < 5/16$ inch: 100% MT after root weld pass and final weld pass
	External (top) fillet weld for socket-type connections	100% MT
Hand holes and other appurtenances	Fillet and PJP welds	MT full length on random 25% of all standard and poles

NOTE: t = pole or arm thickness