

DEPARTMENT OF TRANSPORTATION
DIVISION OF ENGINEERING SERVICES
OFFICE ENGINEER, MS 43
1727 30TH STREET
P.O. BOX 168041
SACRAMENTO, CA 95816-8041
FAX (916) 227-6214
TTY 711



*Flex your power!
Be energy efficient!*

May 26, 2010

10-SJ-205-1.9/R7.9
10-0Q2704

Addendum No. 1

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN SAN JOAQUIN COUNTY NEAR TRACY AT VARIOUS LOCATIONS FROM 0.6 MILE EAST OF PATTERSON PASS ROAD OVERCROSSING TO 0.9 MILE EAST OF TRACY BOULEVARD UNDERCROSSING.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Tuesday, June 8, 2010.

This addendum is being issued to revise the Project Plans, and the Notice to Bidders and Special Provisions.

Project Plan Sheets 38, 167, 168, 169, and 170 are revised. Copies of the revised sheets are attached for substitution for the like-numbered sheets.

In the Special Provisions, Section 5-1.11, "SUPPLEMENTAL PROJECT INFORMATION," is revised as attached.

In the Special Provisions, Section 10-3.13, "MICROWAVE VEHICLE DETECTION SYSTEM - SIDE FIRE," subsection "TECHNICAL REQUIREMENTS," the sixth paragraph is revised as follows:

"Field terminated circuits shall include transient protection that complies with IEEE Standard C 62.41.2."

In the Special Provisions, Section 10-3.13, "MICROWAVE VEHICLE DETECTION SYSTEM - SIDE FIRE," subsection "TECHNICAL REQUIREMENTS," the following paragraph is added after the seventh paragraph:

"At the Contractor's option, the surge protection module may be internal to the MVDS sensor."

Addendum No. 1
Page 2
May 26, 2010

10-SJ-205-1.9/R7.9
10-0Q2704

To Bid book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the Notice to Bidders section of the Notice to Bidders and Special Provisions.

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the Bid book.

Submit bids in the Bid book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This addendum and attachments are available for the Contractors' download on the Web site:

http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/10/10-0Q2704

If you are not a Bid book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

IGNACIO SANCHEZ DEL REAL
Acting Office Chief
Office of Plans, Specifications & Estimates
Office Engineer
Division of Engineering Services

Attachments

5-1.11 SUPPLEMENTAL PROJECT INFORMATION

The Department makes the following supplemental project information available:

Supplemental Project Information

Means	Description
Included in the Information Handout	Geotechnical Design and Materials Report
Available at: http://www.dot.ca.gov/hq/esc/oe/weekly_ads/index.php	Cross sections