

DEPARTMENT OF TRANSPORTATION

DES-OE MS #43
1727 30TH Street, 2ND Floor
Sacramento, CA 95816



**** WARNING ** WARNING ** WARNING ** WARNING ****
This document is intended for informational purposes only.

Users are cautioned that California Department of Transportation (Department) does not assume any liability or responsibility based on these electronic files or for any defective or incomplete copying, excerpting, scanning, faxing or downloading of the contract documents. As always, for the official paper versions of the bidders packages and non-bidder packages, including addenda write to the California Department of Transportation, Plans and Bid Documents, Room 0200, P.O. Box 942874, Sacramento, CA 94272-0001, telephone (916) 654-4490 or fax (916) 654-7028. Office hours are 7:30 a.m. to 4:15 p.m. When ordering bidder or non-bidder packages it is important that you include a telephone number and fax number, P.O. Box and street address so that you can receive addenda.

February 22, 2002

10-Mer-5-1.0
10-1A4304
ACIMG-005-5(127)385E

Addendum No. 2

Dear Contractor:

This addendum is being issued to the contract for construction on State highway in MERCED COUNTY ABOUT 24.2 km SOUTH OF LOS BANOS AT JOHN "CHUCK" ERRECA SAFETY ROADSIDE REST AREA.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on February 26, 2002.

This addendum is being issued to revise the Notice to Contractors and Special Provisions.

In the Special Provisions, Division 1.15, "SANITARY FACILITIES", is revised as attached.

To Proposal and Contract book holders:

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the proposal.

Submit bids in the Proposal and Contract book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This office is sending this addendum by confirmed facsimile to all book holders to ensure that each receives it.

If you are not a Proposal and Contract book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

REBECCA D. HARNAGEL, Chief
Office of Plans, Specifications & Estimates
Office Engineer

Attachment

1.15 SANITARY FACILITIES

When operational, State sanitary facilities will be available for use by the Contractor's employees. Tools shall not be cleaned nor shall cleaning liquids be disposed of in State sanitary facilities or sewers.

During toilet room renovation or other periods when State-owned sanitary facilities are not operational, the Contractor shall provide and pay for temporary toilet units for public use as follows:

- 2 Mens units
- 2 Womens units
- 1 Handicap accessible unit

Separate toilet facilities shall be provided for Contractor personnel. All units shall include the periodic flushing, waste removal and cleaning of such facilities. Units shall be maintained in a clean and sanitary condition, by the Contractor 7 days per week, including a supply of toilet tissue, toilet seat covers, paper towels and hand sanitizers.

Temporary units.--Temporary toilet units shall be single occupant units of the chemical type properly vented and fully enclosed with a glass fiber reinforced polyester shell or similar nonabsorbent material.

Sanitary waste disposal.—All sanitary waste material shall be removed from each toilet unit once per day. Sanitary waste material shall be disposed of off site in a lawful manner.

If the Engineer orders additional removal of sanitary waste, additional removal will be paid for as an ordered change in conformance with the provisions in Section 3, "Changes in the Work," of the General Conditions.

Temporary drinking fountains.--Contractor shall provide and install temporary public drinking fountains, one at each Roadside Rest Area, at locations shown on the plans. Fountains shall be reinforced concrete with exposed aggregate finish. Fountains shall be equipped with stainless steel bowl, vandal-resistant, recessed push-button valve, concrete bubbler guard, weather-resistant, chrome-plated bubbler and waste strainer, stainless steel access plate for field service, and loose key or keyless type hose faucet with integral or nonremovable backflow preventer on the back, 32 mm drain, screwdriver or allen-wrench stop, and vandal resistant bottom plate fasteners. Drinking fountains shall be Haws, 3177; Sunroc, SF-8250; Halsey Taylor, 4590; or equal.