

**DEPARTMENT OF TRANSPORTATION**

DIVISION OF ENGINEERING SERVICES

OFFICE ENGINEER

1727 30<sup>th</sup> Street MS-43

P.O. BOX 168041

SACRAMENTO, CA 95816-8041

FAX (916) 227-6214

[www.dot.ca.gov/hq/esc/oe](http://www.dot.ca.gov/hq/esc/oe)*Flex your power!  
Be energy efficient!*

March 17, 2014

11-Imp-86-11.3 / 20.6

11-2M5104

Project ID 1100020425

Addendum No. 2

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN IMPERIAL COUNTY IN AND NEAR IMPERIAL AND BRAWLEY FROM 15TH STREET TO SOUTH JUNCTION ROUTE 78.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Thursday, March 20, 2014.

This addendum is being issued to revise the *Notice to Bidders and Special Provisions*.

In the Special Provisions, Section 37, "BITUMINOUS SEALS," is replaced as attached.

To *Bid* book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the *Notice to Bidders* section of the *Notice to Bidders and Special Provisions*.

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the *Bid* book.

Submit bids in the *Bid* book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This addendum and attachment are available for the Contractors' download on the Web site:

[http://www.dot.ca.gov/hq/esc/oe/project\\_ads\\_addenda/11/11-2M5104](http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/11/11-2M5104)

If you are not a *Bid* book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

A handwritten signature in black ink, appearing to read "Laurie Berman".

*L* LAURIE BERMAN  
District Director

Attachment

**Add to section 37-2.05B(2)(b) of the RSS for section 37-2:**

Asphalt binder for asphalt rubber binder seal coat must be Grade PG 70-10.

**Add to section 37-2.05B(2)(e) of the RSS for section 37-2:**

Screenings for asphalt rubber seal coat must comply with the medium grading.

**Add to section 37-2.05B(3)(d) of the RSS for section 37-2:**

If you request to use a variable application rate apparatus and the Engineer authorizes, the rate in the wheel paths may be reduced to 0.50 gal/sq yd.