



**NOTES:**

1. Dimensions are nominal.
2. The steel pedestal, base plate, and bolt circle for the telephone demarcation cabinet shall be the same as that shown for a Type 1-C Standard. The steel pedestal shall be 2'-1" to 2'-6" in length. Anchor bolts shall be 3/4" ø x 1'-6" with a 2" - 90° bend. Four bolts required per cabinet.
3. Telephone interconnect conductors shall be enclosed in a 3/4" or larger conduit through the foundation. Type 4 conduit shall be used to separate telephone and power conductors in the cabinet and pedestal.
4. Mount cabinet on Type G cabinet pedestal and foundation (see RSP ES-3B).

DIST	COUNTY	ROUTE	POST MILES TOTAL PROJECT	SHEET NO.	TOTAL SHEETS

Theresa Gabriel  
REGISTERED ELECTRICAL ENGINEER

April 15, 2016  
PLANS APPROVAL DATE

Theresa Aziz Gabriel  
No. E15129  
Exp. 6-30-16  
ELECTRICAL  
STATE OF CALIFORNIA

THE STATE OF CALIFORNIA OR ITS OFFICERS OR AGENTS SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF SCANNED COPIES OF THIS PLAN SHEET.

TO ACCOMPANY PLANS DATED \_\_\_\_\_

**FASTENER SCHEDULE**

BACKBOARD	4 - 3/4" (LENGTH) WOOD SCREWS
2 SHELF SUPPORTS	4 - 3/4" (LENGTH) WOOD SCREWS
JUNCTION BOX	4 - 1/2" (LENGTH) WOOD SCREWS
TERMINAL BLOCK	4 - 3/4" (LENGTH) WOOD SCREWS

STATE OF CALIFORNIA  
DEPARTMENT OF TRANSPORTATION

**ELECTRICAL SYSTEMS  
(TELEPHONE DEMARCATION  
CABINET, TYPE A)**

NO SCALE  
RSP ES-3D DATED APRIL 15, 2016 SUPERSEDES STANDARD PLAN ES-3D  
DATED OCTOBER 30, 2015 - PAGE 431 OF THE STANDARD PLANS BOOK DATED 2015.

**REVISED STANDARD PLAN RSP ES-3D**

2015 REVISED STANDARD PLAN RSP ES-3D