



**ELEVATION A**

POLE TYPE	POLE DATA				BASE PLATE DATA			CIDH PILE FOUNDATION		
	A HEIGHT	Min OD BASE	TOP	Min THICKNESS	C	BC = BOLT CIRCLE	THICKNESS	ANCHOR BOLT SIZE	Diα	DEPTH
32	35'-0"	10 3/4"	5 1/2"	0.1793"	1'-5"	1'-3"	2"	1 1/2" φ x 42"	3'-0"	8'-0"



**DETAIL A**



**BASE PLATE DETAIL  
DETAIL C**

DIST	COUNTY	ROUTE	POST MILES TOTAL PROJECT	SHEET No.	TOTAL SHEETS


*Stanley P. Johnson*  
 REGISTERED CIVIL ENGINEER  
 No. 05735  
 Exp. 3-31-18  
 CIVIL  
 STATE OF CALIFORNIA

July 15, 2016  
 PLANS APPROVAL DATE  
 THE STATE OF CALIFORNIA OR ITS OFFICERS OR AGENTS SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF SCANNED COPIES OF THIS PLAN SHEET.

TO ACCOMPANY PLANS DATED \_\_\_\_\_

**NOTES:**

1. Handhole shall be located on the downstream side of traffic.
2. For additional notes and details, see Revised Standard Plans RSP ES-7M and RSP ES-7N.



**POLE SPLICE  
DETAIL B**

STATE OF CALIFORNIA  
DEPARTMENT OF TRANSPORTATION  
**ELECTRICAL SYSTEMS  
(LIGHTING STANDARD,  
TYPE 32)**

NO SCALE

RSP ES-6G DATED JULY 15, 2016 SUPERSEDES STANDARD PLAN ES-6G  
DATED OCTOBER 30, 2015 - PAGE 455 OF THE STANDARD PLANS BOOK DATED 2015.

**REVISED STANDARD PLAN RSP ES-6G**

2015 REVISED STANDARD PLAN RSP ES-6G