

Job Stamp
04-0220L4
OTD1
04-0120J4(SWTS)
04-ALA-80-2.5/5.6
Projects

STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION
Mehran Ardakanian
CONSTRUCTION ENGINEER'S
DAILY REPORT

File No.: **45**
Report No. 271-277
Date: Sept. 10 – 16, 2007
MTWTFSS

Monday #271 09-10-2007 --

- Updated the lotus notes server, so I could use it via staff central, when I am away from the office.
- Updated the on-line car log.
- Created an O.T. log, so I could utilize it when approving Ben's staff timesheet, as I get over 18 timesheets for both the J and OTD job for District and Structures staff on a weekly basis.
- Generate timesheet log for the month of September.
- Reviewed staff's timesheet for approval.

Tuesday #272 09-11-2007 --

- Reviewed staff's timesheet for approval.
- Requested staff to provide me a copy of their daily reports weekly on Fridays, until the PMIV is set up.
- Contacted Chris Calvi, Xavier Avila's supervisor, regarding his immediate transfer to OSC and be on loan to Chris until prior to Nov. 1st, where he'll be reporting to OSC. Chris showed no objection and informed me that Xavier is currently on a leave of absence and is also currently on loan to OSC. Chris will sign any release forms that is required to make the transfer final. Emailed Sherry Hass to start the paper work process.

Wednesday #273 09-12-2007 --

- Emailed staff regarding Overtime policy, cc'd the deputy directive No. DD-56.
- Attended the safety meeting at 8 on confined space procedures.
- Vincent Rodriguez of Corpac Steel (305-933-8599) called to make sure the carbon equivalency of 0.45 is per A-709, I checked with Richard Chang, he apparently left out the A709 from the response letter and will issue a new letter adding the A709.
- Attended the 1-2 Welding/Design Team Champion Meeting.
- Attended the 2 p.m. ISD meeting with MCM & Design Team. Major issue is the #18 hoops around the piles (foundation), with the allowable ACI variation tolerance, it would be very difficult, if not possible to place rebar, Harris Salinas Rebar proposed to replace the #18's with 4-1/2" strands. Design to look into it.
- Reviewed and corrected 4 letters drafted by Richard Chang, there needs to be more attention dedicated to details, as many grammatical and other errors were found. I was able to correct all and with Reba's assistance get the letters out to MCM.

Thursday #274 09-13-2007 --

- Contract Administration.


Mehran Ardakanian
Senior RE/Bridge Construction Engineer

Job Stamp
04-0220L4
OTD1
04-0120J4(SWTS)
04-ALA-80-2.5/5.6
Projects

STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION
Mehran Ardakanian
CONSTRUCTION ENGINEER'S
DAILY REPORT

File No.: **45**
Report No. 271-277
Date: Sept. 10 – 16, 2007
MTWTFSS

Friday #275 09-14-2007 --

- Requested Greg to provide the pile hammer information for the trestle pile work.
- Attended a meeting called by Amer to discuss division of work among field staff.
- Returned Andy's phone call regarding our letter 79, in response to RFI 10, he seems that there is confusion, I left him a message that it is correct and HSR is asking items regarding the ISD's. Also, asked him to revise his submitted pile lifting holes, as the lower portion holes is not allowed, so need to propose a different option and the upper hole locations to be resubmitted, as they need to be 6" way from the shear rings.
- Called Markian and provided Steward Machine's name and contact for him to call, so they could go over the comments by METS on the WQCP. Called Andy and informed him that I did get his message on this subject and forwarded the info. to Markian.

Saturday #276 09-15-2007 --

- No work performed.

Sunday #277 09-16-2007 --

- No work performed.



Mehran Ardakanian
Senior RE/Bridge Construction Engineer