

JOB STAMP
04-0120M4 (04-00000022)
04-SF-80-1.6/2.7
San Francisco Oakland Bay Bridge
Oakland Touchdown - Phase 2

REPORT NO.	09	to	DATE	June 13, 2012	M T W Th F S S
SHIFT HOUR	START	07:00	STOP	16:30	TEMPERATURE
WEATHER	Clear				

1. Continue to fill in for Stanley Ku on the SAS project – WDC.
2. Site Meeting with the SFMTA on the Central Subway Project.
3. Contacted Mohan Char, AECOM, and they will have drawings for the revised abutment footing ready tonight or tomorrow morning for signing by Hasan. Received draft copy in the afternoon and forwarded onto FWI.
4. Contacted Ernie Holt to determine availability for a DRB Board position.
5. Request from FWI to expedite review of the WQCP for RCB Lubron. Based upon initial reviews it appears to be incomplete.
6. Received comments back for the Micropile review. Son Ly will also look into the Value Engineering Package submitted for the sign foundation substitution.
7. Staff working on survey of the existing bicycle path from the OTD I contract.
8. Received product list for headed reinforcing steel from CMC rebar. Will have Chetan respond back with a letter addressing the need for a coupler meeting and reminder of their responsibilities regarding a work plan.
9. Received pile handling plan, misc metal shop drawings & the bridge deck drainage system submittals.
10. Sent question to K C Liu, Signs and Overhead Structures, regarding the base plate of the folding handrail being the same width as the flange of the support beam making a fillet weld difficult if not impossible. Will redline the shop drawings to use a pjp weld at this location or allow for the option of using a larger base plate to support a fillet weld. Sent back the sign structure shop drawings "Approved as Noted."
11. Sent out a meeting request to discuss the Lubron WQCP with FWI, Lubron and METS.

SIGNATURE Gary Lai, Original Signed	TITLE Structures Representative
---	------------------------------------