




STATE OF CALIFORNIA - DEPARTMENT OF TRANSPORTATION
Caltrans
 DESIGN OVERSIGHT
 BEHZAD GOLEMOHAMMADI



CABLE TRAY PLAN - DETAIL 4
 SCALE 1:40



PIPE SLEEVE LOCATION
 NO SCALE



CABLE TRAY PLAN - DETAIL 5
 SCALE 1:40



DIST	COUNTY	ROUTE	KILOMETER TOTAL PROJECT	POST PROJECT	SHEET No	TOTAL SHEETS
04	SF	80	13.2/13.9		166 S1	1204

REGISTERED ELECTRICAL ENGINEER DATE 2/22/08
 S. A. ESTOQUE, JR.
 No. E-10151
 Exp. 12/31/2008
 ELECTRICAL
 STATE OF CALIFORNIA

PLANS APPROVAL DATE
 PB AMERICAS, Inc.
 A Parsons Brinckerhoff Company
 303 Second St., Suite 700N
 San Francisco, CA 94107-1317

The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this plan sheet.
 Caltrans now has a web site! To get to the web site, go to <http://www.dot.ca.gov>

NOTES:

- Reference:
 - For circuit, conduit/cable tray schedules, see sheets starting at E-401.
- For location of pipe sleeves at the Crossbeam/Service platform, see Typical crossbeam details sheets.
- For cable tray support details, see AS sheets.
- (SP) Denotes spare pipe sleeve for 103 mm. Contractor to provide plug at each ends.

SHEET NOTES:

- For continuation inside WB girder, -at Crossbeam #4, see sheet E-96.
- For continuation inside EB girder, -at Crossbeam #4, see sheet E-181.
- For continuation inside Crossbeam,

REQUEST FOR INFORMATION NOT ADDRESSED IN THIS CCO REMAIN IN FORCE					
02/25/08	CABLE TRAY CHANGES	SPO	RG SE	42S1	
MARK	DATE	DESCRIPTIONS	BY	CH'D	CCO#
		REVISIONS			

CONTRACT CHANGE ORDER NO. _____
 SHEET _____ OF _____


DETAILS
SAS SUPERSTRUCTURE GIRDER WESTBOUND
CONDUIT, GROUNDING AND CABLE TRAY PLAN

SCALE AS NOTED

E-114A

THIS PLAN IS ACCURATE FOR ELECTRICAL WORK ONLY.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN



DGN FILE => T:\13103\MS\pse\SAS Struc\CCO\SAS CC04251\04-0120F1_0166501.dgn
 USERNAME => kurnovskaya
 CU 04251

EA 0120F1

DATE PLOTTED => 2/26/2008
 TIME PLOTTED => 1:30:41 PM
 00-00-00