

CONTRACT CHANGE ORDER NO. 43 SUPPL. NO. 0
ROAD 04-SF-80-13.2, 13.9 SHEET 3 OF 42 SHEETS
FEDERAL NO.(S) _____ CONTRACT NO.: 04-0120F4

Special Provisions changes:

In the Special Provisions, add the following sub-section to section 10-3 "ELECTRICAL SYSTEMS", after Section 10-3.10 "CONDUCTORS, CABLES AND WIRING".

10-3.105 FUSED SPLICE CONNECTORS

Fused splice connectors shall be provided on all fixtures as indicated on the contract plans in accordance with Section 86-2.095 "Fused Splice Connectors", of the Standard Specifications. Waterproof splice (boot) is not required when fused splice connector is installed inside Nema 4X-type enclosure.

