



SFOBB - SAS Project
Two Harrison Street, Suite 500, San Francisco, CA 94105
Telephone (415) 291-3700 Facsimile (415) 433-0807

REQUEST FOR INFORMATION (RFI) RESPONSE

SFOBB SAS Project # 04-0120F4

To: Caltrans
333 Burma Road
Oakland, CA 94607

Date: August 20, 2013
Date Received: August 15, 2013
Contract No: 04-0120F4
04-SF-80-13.2/ 13.9

Attn: Stanley Ku

Job Name: SAS Project - SFOBB

RFI No.: 3452R0

Subject: Barrier Conduit: Additional Penetrations

Background:

None.

Response to RFI:

The Design JV takes no exception to the Contractor's proposal to provide conduit penetrations in the barrier cover plates. Cover plate hood assemblies shall be provided at all penetrations as shown on Sheet 889S1.

The requested penetration locations listed in the text of the RFI at PP119 + 550mm and PP119 + 1450mm appear not to match the corresponding photo of the RFI, which shows requested penetrations at approximately PP119 + 1450mm and PP119 + 1950mm.

PB to respond regarding locations of the penetrations.

Attachment to RFI Response:

None.

Internal JV Action:

None

Potential Design / Cost Impact: No Change
 Change w/ No Cost
 Change w/ Cost
 Change w/ Credit

Potential Time Impact: No
 Yes

Answered By: D. Turner

QA / QC By: M. Nader, J. Duxbury

CC: File: TYLIN/MN