

OK

STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION
Form HC-10A (Rev. 6/80)

Job Stamp 04-0120F4 SFOBB SAS

Report No.	170
Date	6/1/2007
Shift Hours	Start <u>0700</u> Stop <u>1530</u>


ASSISTANT RESIDENT ENGINEER'S **CONTRACTOR - ABFJV**

HOURS - ITEM NO.												REMARKS		
EQUIPMENT AND/OR LABOR:			#38 Str. Concrete, Bridge									IDLE OR DOWN	Name	Contractor
Equip. #	NO. MEN	DESCRIPTION (Of Equipment or Labor)												

Weather: Foggy/ Sunny - Hi 70F Lo 50F.

Description of Operation:

W2 crossbeam falsework construction
ABF continued to erect the falsework posts at W2W.
In a conversation with Steve Marko and Terry Crunk, we discussed about bolted connection between posts and column bracing. I told Steve that bolts for the connections are supposed to be hand-tightened in order some movement for the final grading. ABF was using a pneumatic ranch to tightened the bolts.

Inspector: Ken Lee  Trans Engineer (D)