STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION

Form HC-10A (Rev. 6/80)

Job Stamp

04-0120F4
SFOBB SAS

Report No.

Date **12/03/2007**

Inspectors Hours	Start	08:15	Stop	12:00
Shift Hours	Start	07:00	Stop	15:30

ASSISTANT RESIDENT ENGINEER'S **CONTRACTOR – ABFJV, Sub RPS**

Description of Operations @ W2 Cap Beam:

RPS:

- RPS foreman Lance Gaige wanted to use 2" dobbies instead of 2.5" dobbies with #16 berry bar. I told him it was unacceptable and the specified cover is 80mm or 3". RPS had to get 2.5" dobbies offsite since the 2" dobbies were the only size shipped to the jobsite. RPS spent the rest of the day mobilizing #16 berry bars.
- Song and myself checked the previously cut bars @ pier top slabs per sheets 486S1 and 486S2.

Office Work:

- Reviewed plans and specifications for W2 cap beam and worked on miscellaneous paperwork

Inspector:

Matt Bruce Matt Bruce Transportation Engineer (D)

RECD 07 DEC 29 #002992