

STATE OF CALIFORNIA – DEPARTMENT OF TRANSPORTATION  
**RESIDENT ENGINEER'S DAILY REPORT**  
**ASST. RESIDENT ENGINEER'S DAILY REPORT**  
 DC-CEM-4501-CUSTOM



**04-0120F4**  
**04-SF-80-13.2/13.9**  
**SAS**

RESIDENT ENGINEER'S DAILY REPORT – FILE CAT. 45

ASST. RESIDENT ENGINEER'S DAILY REPORT – FILE CAT. 46

REPORT NO.: <b>362 to 366</b>	DATE: <b>12/10 to 12/14/07</b> S <input type="checkbox"/> M <input type="checkbox"/> T <input type="checkbox"/> W <input type="checkbox"/> T <input type="checkbox"/> F <input type="checkbox"/> S (Circle Day)
SHIFT HOUR: START; <b>07:30</b> STOP; <b>16:00</b>	TEMPERATURE: MIN; <b>NA</b> MAX; <b>NA</b>
WEATHER: <b>(NA – See Weekly Statement of Working Days)</b>	

- Monday: 12/10/07 0730 - 1600 = 8 hrs
- Monterey Mechanical technician was on site checking on the A/C units for the Mission Bay trailers.
  - Chaired the CCO 14 meeting.
  - Called Christina of Corner Office again to inquire the purchase order for modifying the file cabinets. Did not receive call back.
  - Reviewed and approved the revised invoice from CECO for the fire alarm work over at the Waterfront.
- Tuesday: 12/11/07 0730 - 1600 = 8 hrs
- Attended MEP RFI meeting in the morning.
  - Worked on RFI-1066.
  - Called Andy of PMI to inquire status of the HVAC diagnostic done yesterday. He checked with Monterey Mechanical and adjustment was made to the thermostats and dampers to “optimize” the air flow. He wanted us to keep the settings untouched for the next few days to see if the problem was fixed. I talked to Charday & Marie and found out they already made adjustments to the thermostats because the trailers were too “cold” this morning.
  - I discussed with Ignacio of TMP about the crossover for the retaining wall.
  - Called and left message for Tom of McKinley Elevator inquiring the whereabouts of the new list of punchlist items. Did not receive call back.
- Wednesday: 12/12/07 0730 - 1600 = 8 hrs
- Continued to work on RFI-1066.
  - Sent e-mail to Tom of McKinley Elevator regarding withholding payment on the submitted invoice.
  - Reviewed and commented on the meeting minutes.
- Thursday: 12/13/07 0730 - 1600 = 8 hrs
- Attended the bi-weekly safety and staff meeting.
  - Provided response on RFI-1066.
- Friday: 12/14/07 0730 - 1600 = 8 hrs
- Attended the MEP CCO meeting in the morning.
  - Called Andy of PMI and followed up on the crossover for the retaining wall. Don called me back and we agreed to go ahead with the order for 8’ wide stairs. He would provide sketch to confirm next week.
  - Talked to Christina regarding the purchase order for retrofitting the file cabinets. She assured I would receive one soon.

SIGNATURE

**Paul Chui, P.E.**

TITLE

**Consultant Engineer, SAS**