

Job Stamp
04-0120F4
SFOBB SAS

Const. Calendar Day No. 725
Project Work Day No. 935
Date 12/07/2008
Shift Hours Start 0.00 Stop 24:00
Inspector Shift 9-12

ASSISTANT RESIDENT ENGINEER'S CONTRACTOR - ABFJV

| | | | HOURS - ITEM NO. | | | | | | | | | | | | | |
|-------------------------|---------|-------------------------------------|---------------------------|------------------------------|-----|--|--|--|--|--|--|--|--|--------------|---------|------------|
| EQUIPMENT AND/OR LABOR: | | | #38 Str. Concrete, Bridge | # 48 Bar Reinforcement Steel | CCO | | | | | | | | | IDLE OR DOWN | REMARKS | |
| Equip. # | NO. MEN | DESCRIPTION (Of Equipment or Labor) | | | | | | | | | | | | | Name | Contractor |
| | | | | | | | | | | | | | | | | |

Work at E2 Site:

- a) Myself and Ron Matin observed the water temperature and water flow for thermal cooling. The water was flowing in at 49 F and coming out at 52 F. The water was flowing at 280 GPM into the southern Manifolds and 400 GPM in to the northern manifolds.
- b) The chiller was cooling the water to 43 F. The temperature gage for incoming water was not working. A total of 350 GPM was flowing into the chiller.
- c) ABF's Branden was supposed was there too.
- d) ABF had 3 people on the site manning the cooling operation of E2.

Total OT for today 4 hours.

Lalit Mathur
Lalit Mathur, P.E. Trans Engineer (D)/Asst. Struct. Rep

46.02