STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION

Form HC-10A (Rev. 6/80)

Job Stamp
04-0120F4
SFOBB SAS

Const. Calendar Day No. 732
Project Work Day No. 942
Date 12/14/2008

Shift Hours Start 0.00 Stop 24:00
Inspector Shift Midnight to 9 to 11

ASSISTANT RESIDENT ENGINEER'S **CONTRACTOR – ABFJV**

EQUIPMENT AND/OR LABOR:

Equip. #	NO. MEN	DESCRIPTION (Of Equipment or Labor)	HOURS - ITEM NO. #38 Str. Concrete, Bridge	# 48 Bar Reinforcement Steel	CCO							IDLE OR DOWN	REMARKS Name	Contractor

Work at E2 Site:

a) Came to check the general cover and temperatures.
b) Branded had already taken the readings.
c) The readings show that the temperatures were as follows:

Top	28 C
Bottom	33 C
Center	43 C

d) I observed the water temperature and water flow for thermal cooling.
e) The water was flowing in at 48 F and coming out at 50 F. The water was flowing at 750 GPM.
f) The chiller was cooling the water to 43 F.

Total OT for today 4 hours.

Lalit Mathur, P.E. for [illegible] Trans Engineer (D)/Asst. Struct. Rep

 REC'D 09 JAN 06 #008220

46.02