

JOB STAMP

04-0120F4  
 04-SF-80-12.6/13.2  
 San Francisco Oakland Bay Bridge  
 Self Anchored Suspension Span

REPORT NO.	970	to	976	DATE	Aug 9– Aug 15, 2009	S T W Th F S
SHIFT HOUR	START	Var.	STOP	Var.	TEMPERATURE	
WEATHER	Sunday	Monday –	Tuesday –	Wednesday –	Thursday –	Friday –Saturday –

**9 August**

No Work on Site

**10 August**

Worked 2 hours overtime.

1. Reviewed email and PMIV Correspondence.
2. Prepared multiple submittals to be sent to the Contractor with most of the WDC staff. Mainly lifts 13 and 14 submittals were the focus for the month of August.

**11 August**

Worked 2 hours overtime.

1. Reviewed email and PMIV Correspondence.
2. Attended East End TVC-RFI Meeting. **See attachment.**
3. Prepared multiple submittals to be sent to the Contractor with most of the WDC staff. Mainly lifts 13 and 14 submittals were the focus for the month of August.

**12 August**

Worked 2 hours overtime.

1. Reviewed email and PMIV Correspondence.
2. Attended East End TVC-RFI Meeting. **See attachment.**
3. Prepared multiple submittals to be sent to the Contractor with most of the WDC staff. Mainly lifts 13 and 14 submittals were the focus for the month of August.

**13 August**

Worked 2 hours overtime.

1. Reviewed email and PMIV Correspondence.
2. Attended a 1 hour Safety Meeting.
3. Attended East End TVC-RFI Meeting. **See attachment.**
4. Prepared multiple submittals to be sent to the Contractor with most of the WDC staff. Mainly lifts 13 and 14 submittals were the focus for the month of August.

**14 August**

Worked 2 hours overtime.

1. Reviewed email and PMIV Correspondence.
2. Prepared multiple submittals to be sent to the Contractor with most of the WDC staff. Mainly lifts 13 and 14 submittals were the focus for the month of August.

**15 August**

Worked 8 hours overtime.

1. Prepared multiple submittals to be sent to the Contractor with most of the WDC staff. Mainly lifts 13 and 14 submittals were the focus for the month of August.

RECT H32 FEB 03 #1011867

Victor Altamirano SIGNATURE <i>Victor Altamirano</i>	TITLE
Senior SIGNATURE <i>Victor Altamirano</i>	Transportation Engineer / Assistant Struct. Rep.

2-Nov-09  
 JAN 13 2010  
 "Caltrans improves mobility across California"

**11-Aug-09**  
DJV Teleconference Meeting @ 9am

**Attendees:**

**DJV**  
**Caltrans**  
**METS**

---

**DJV may need an FTP site.**

**Pipe Sleeve**

Based on METS calculations, 3 seams total are needed. METS will follow-up with Hayat to provide her with some drawings.

**Plate thickness transition @ butt welds**

1:10 skin plate

1:2.5 floorbeam

For 60 to 100mm skin plate, 1:2.5 transition

For 30 to 65mm skin plate, 1:2.5 transition

Dan will provide Matrix to Hayat to show Rolf.

**Attendees:**


**DJV**  
**Caltrans**  
**METS**

---

**Pipe Sleeve**

Hayat will generate a TVC-RFI.

**Weld detail for 3mm plate offsets:**



DJV: At shop splice, transitions are 1:10 for Girder  
1 to about 2 mm gap for fillet welds.  
1:2.5 transitions for floorbeam stiffener.

DJV: Is there an issue with the 1:2.5 transitions in kink?

METS: Issue may be the fillet weld.

Possible solution: Mill to bear and add fillet.

Possible solution for DJV: To define 1:10 & 1:2.5 transitions.

Weld intersecting each other is difficult to inspect.

Hayat will verify what submittal affects this weld transition.

**12-Aug-09**  
DJV Teleconference Meeting @ 9am

**Attendees:**

**DJV**

**Caltrans**

**METS**

---

**Lifting Lugs – Lift 14 versus Lift 13**

Hayat: Candraft may change location of lifting lugs, this will make it hard to make redlines. This applies to both Lift 13 and 14. DJV will only *reference* the submittal 214R10 without redlining any dimensions given that Candraft has plans to change submittal 214R10.

**13-Aug-09**  
DJV Teleconference Meeting @ 9am

**Attendees:**

**DJV** – George Baker, Sam, Hayat, & Dan

**Caltrans** – Victor & Roman

**METS** –

---

- Weld transition: Hayat will get back to Rolf.
- 3+ plates joining in is an issue.
- 2 TVC-RFI closed and 1 is open, but Submittal 847 answers the question. Roman/Hayat will work together on a response.
- Dan emailed Hayat some floorbeam sketches about submittal 949.

**Focus Group**

- Fabrication procedure about approver note, where DJV has been indicated “ABF/ZPMC to respond.” DJV will list the issues. Sam will compile a list of the questions from the approval note for Lift 13 & 14. They can use the list of approver notes provided by ABF in the revision zero (0) submittals. They will include any TVC-RFI’s.

**Pipe Sleeve**

- Genish/Jim to respond.