STATE OF CALIFORNIA • DEPARTMENT OF TRANSPORTATION

RESIDENT ENGINEER'S DAILY REPORT
ASST. RESIDENT ENGINEER'S DAILY REPORT

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/0BB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

REPORT NO. SF0BB - SAS - 0203

DATE 19th July 2007 M T W (T) F S S (Circle Day)

SHIFT HOUR: START 0700 STOP 1630

TEMPERATURE MIN MAX

WEATHER

(1) Review emails & PMIV actions.

(2) Discussion with K. Baltzer Regarding Goodwin Shutdown Schedule

(3) Discussion with R. Crockett regarding RFI #786 - He stated that S.P. don't require testing to verify A709m steel meets fine grain requirements. Testing not reqd if chemistry is met. Ron disputes if contract requires this to be on the Mill Test Report. Ron to explore if Mill Will Provide certification Post Production, as Plate already ordered.

(4) Discussion regarding Sub #157

(5) Attend meeting to discuss Sub #157

SIGNATURE [signature]

TITLE Assistant Structure Representative/ ~~Leadworker~~

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.

12 MAR 19 PM 3:29 18289

CEM4501