STATE OF CALIFORNIA • DEPARTMENT OF TRANSPORTATION

RESIDENT ENGINEER'S DAILY REPORT
ASST. RESIDENT ENGINEER'S DAILY REPORT

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/0BB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

REPORT NO. SFOBB-SAS-0278	DATE 20th Nov 07 M (T) W T F S S (Circle Day)
SHIFT HOUR: START 0700 STOP 2015*	TEMPERATURE MIN MAX

WEATHER

① Review emails & PMIV actions

② Close-out RFI # 1042R0

③ DISCUSSION WITH SMR REGARDING
(A) SUB # 435R0 & R1
(B) SUB's 332R1 & 326R1. — Mets Prepared to Waive audit for Pestige but not for Unytite

④ Discussion with K. Baltzer - ABF Regarding
(A) CWI - INFORMED THAT CSWIP Qualifications are OK
(B) Discussion on Missing Weld map when Rev 1 of Sub #396 submitted.

* ⑤ Discussion with SMR regarding Welding Procedure for Goodwin. Contract requires Welding to D1.5 & Section 5-3 is invoked. Discussion with K. Baltzer regarding this; agreement that for Friction test band, Weld upgrades to ASME IX are acceptable.

⑥ Draft responses to Sub # 332R1 & 326R1 Prepared

* WORKED LATE TO PROVIDE DRAFT RESPONSES TO SUBMITTALS AS A RESULT OF EARLY CUT-OFF TIME 21st NOV

SIGNATURE [signature]	TITLE Assistant Structure Representative/ ~~Leadworker~~

'12 NOR-19 PM 3:38 18364

CEM4501

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.