STATE OF CALIFORNIA • DEPARTMENT OF TRANSPORTATION

RESIDENT ENGINEER'S DAILY REPORT
ASST. RESIDENT ENGINEER'S DAILY REPORT

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/OBB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

REPORT NO. SFOBB-SAS-0362	DATE 21st March 08 M T W T (F) S S (Circle Day)
SHIFT HOUR: START 0700 STOP 1920	TEMPERATURE MIN MAX
WEATHER	

① Review of emails & PMIV actions

② Meeting with ABF 'Bob Kick' to discuss surface finish requirements for stainless steel surface @ hinge K. A finish of 1.6µm is acceptable given Design approval of Sub #549R1 Lubricant & Test report. RFI's #15 & 16, - Advised a contractor requested Change order.

③ Discussion with Bob Kick regarding various JSW issues.

④ Continue review of Sub # 545 R0. NOTE: Discussion with G.LAI regarding time extension.

⑤ Review of RFI # 1243. - Request for Clarification from Designer regarding their response.

⑥ Review of RFI # 1253 - Draft response sent for QA.

⑦ Review of Sub # 570 R0

SIGNATURE	TITLE Assistant Structure Representative/ ~~Leadworker~~

CEM450

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.

'08 MAR 19 PM 3:46 18448