STATE OF CALIFORNIA • DEPARTMENT OF TRANSPORTATION

**RESIDENT ENGINEER'S DAILY REPORT**

**ASST. RESIDENT ENGINEER'S DAILY REPORT**

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/0BB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

| | |
|---|---|
| REPORT NO. SF0BB-SAS-1296 | DATE 27th March 2012 M (T) W T F S S (Circle Day |
| SHIFT HOUR: START 0700 STOP 0815 | TEMPERATURE MIN MAX |
| WEATHER | |

(1) Review emails & PMW actions.

(2) Discuss testing of Cable Band bolts & Test results with Tai-Lin Liu & Kit Guest.

(3) Discuss RFI # 2759R00 with B. Boal. Modify response & discuss with Certified Coatings Prior to Processing.

(4) Discuss Sub # 2583R01 with B. Boal; Review storage of Materials requirements.

(5) Discuss RFI # 2772 with Bill Shedd. K. Balker called to request Expedited review & response. // Provide compressed file attachment to the DJV due to Copy Provided by ABF being 19MB and therefore will not have been received by the DJV // Discuss Weld aspect of RFI with K. Guest.

(6) Discuss splicing of wires on south side span with K. Balker & R. Granados.

(7) Inspect Wrapping demonstration operations:

Step # 5: Completed, two tests splicing wires with Cadwelds Performed.

Step # 6: started, one wire welded utilizing Microwelder - Butt Welding Machine

(8) Discuss Painting of Tower & Inspection with S. Scholifard, M. Awal & D. Wright. Also discuss Pressure Washing & SWPPP requirements / Containment.

(9) Discuss De-railment of hauling line (two occasions) during hauling of PWS # 117(?) in Strong Wind Conditions.

OT = 4 hours — ~~tws~~ c/system / wrapping documentation.

| | |
|---|---|
| SIGNATURE [signature] | TITLE Assistant Structure Representative/ ~~Leadworker~~ |

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.

CEM450

12 JUL -9 AM 9:26 20426