STATE OF CALIFORNIA • DEPARTMENT OF TRANSPORTATION

RESIDENT ENGINEER'S DAILY REPORT
ASST. RESIDENT ENGINEER'S DAILY REPORT

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/0BB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

REPORT NO. SF0BB-SAS-1275

DATE 27th Feb 2012 (M) T W T F S S (Circle Day

SHIFT HOUR: START 0700 STOP 1800

TEMPERATURE MIN MAX

WEATHER

1. Review emails & PMW actions
2. CK Johnson have yet to submit update to west loop shroud drawings per discussion with K. Guest.
3. Discuss submittal #1545R01 with DJV: Reiteration that review is not required as they had completed their review in Sub# 888R03
4. Discuss adjustment of PWS with B. Boal & R. Granados
5. Provide calculation on hours worked on Project since June 2011 per B. Casey's direction.
6. Discuss MCP modifications to Stanchion Posts with B. Shedd & Martin Chandrawinata
7. Discuss RFI #1746R00 with K. Baltzer & M. Chandrawinata.
8. Discuss Manpower for C/works with R. Granados.
9. Attend SAS all staff meeting
10. Discuss lack of lock nuts on PWS Rods and fact that strand #4 on North moved from Match-Marked Position with B. Bignano.
    Note: Detail of lock nut not covered in Sub #1461R00 - Details in #2447R01
11. Discuss ABF's continued use of screwdrivers on PWS wire @ Tower with B. Casey
12. Discuss Sub #2594R00 with B. Boal & DJV.

OT - 2HRS - Submittals / PWS inspection + Shift Cover.

SIGNATURE [signature]

TITLE Assistant Structure Representative/ ~~Leadworker~~

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.

CEM450

12 JUL -9 AM 9:29 20450