STATE OF CALIFORNIA - DEPARTMENT OF TRANSPORTATION

# RESIDENT ENGINEER'S DAILY REPORT
# ASST. RESIDENT ENGINEER'S DAILY REPORT

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/0BB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

| | |
|---|---|
| REPORT NO. SFOBB-SAS-1249 | DATE 23rd Jan 2012 (M) T W T F S S (Circle Day) |
| SHIFT HOUR: START 0700 STOP 1945 | TEMPERATURE MIN MAX |
| WEATHER | |

1. Discuss adjusting of strands with A. Schmidt & K. Baltzer
2. Attend SAS staff meeting
3. Discuss tolerance of strand adjustment in west loop with DJV. ABF say that they're unable to get strand #4 closer than 40mm from theoretical.
   - ABF performed "final" adjustment of strand #3 in side spans
4. Discuss CCO#185 Neoprene protection for sockets & strands with B Brannan & DJV.
5. Meeting with ABF (K. Baltzer, K. Smith) to discuss strand adjustment
6. Prepare executive summary for strand #1
7. Attend on-site discussion with ABF/DJV & CT on PWS issues

SIGNATURE

TITLE
Assistant Structure Representative/~~Leadworker~~

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.

CEM450

12 JUL 5 PM 1:54 20476