STATE OF CALIFORNIA • DEPARTMENT OF TRANSPORTATION

RESIDENT ENGINEER'S DAILY REPORT

ASST. RESIDENT ENGINEER'S DAILY REPORT

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/0BB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

REPORT NO. SF0BB-SAS-1087

DATE 26th April 2011 M (T) W T F S S (Circle Day

SHIFT HOUR: START 0715 STOP 1600

TEMPERATURE MIN MAX

WEATHER

1. Review emails & PMW actions
2. Discuss ABC PQWP - Sub #764R01 with G. Lai & K Guest.
3. Notify K Baltzer that QA Samples for PWS spherical / Jam nuts were tested and are ok, However some documentation verifying that hardness values are in accordance with ASTM needs to be resolved before the nuts can be released.
4. Discuss Sub #2283R00 with A. Singh and details of forthcoming RFI concerning erroneously drilled hole for Catwalk anchor connection @ east end.
5. Discuss Goodwin visit by M. Wahbeh & T. Anziano with R. Seigenthaler & P. Lowry
6. Review Team Cable Meeting Minutes & attend meeting.
7. Finalize 'draft' schedule outlining duration to replace B11 & B13 C/Bands to meet the architects proposed alternative for Tower Suspenders.
8. Witness Cadweld trials @ Warehouse
9. Discuss anticipated date for resubmittal of Revisions to Sub # 1958 & #1969.
10. Discuss site operations for Cable work with R. Granados

SIGNATURE [signature]

TITLE Assistant Structure Representative/ ~~Leadworker~~

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.

CEM450

'12 JUL -9 AM 9:59 20640