STATE OF CALIFORNIA • DEPARTMENT OF TRANSPORTATION

RESIDENT ENGINEER'S DAILY REPORT

ASST. RESIDENT ENGINEER'S DAILY REPORT

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/0BB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

REPORT NO. SF0BB-SAS-0948

DATE 23rd Sep 2010 M T W (T) F S S (Circle Day

SHIFT HOUR: START 0700 STOP 1630.

TEMPERATURE MIN MAX

WEATHER

(1) Review emails & PMW actions

(2) Attend fortnightly SAS Safety meeting.

(3) Inspect Type I modified split collars & Type I & Type II split collars with K. Baltzer. Agree that Type I & II do not require any remedial work. Type I modified collars to be repaired in accordance with Section 75-1.05 "Galvanizing" ABF may repair just prior to installation — RFI expected.

(4) Inspect Painting operation of Hinge Pipe Beams. Informed Painter that coating thickness is in excess of that specified / required in the response to RFI #2237R00.

(5) Provide comments to Sub #697R06 & discuss with G. Lai

(6) Discuss WireCo costs for re-machining the suspender sockets with Jake VanOnkevort.

(7) Discuss Paint damage to Hinge Pipe Beams with B. Boal & B. Brignano.

SIGNATURE [signature]

TITLE Assistant Structure Representative/ ~~Leadworker~~

'12 JUL-9 PM 3:45 20800

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.

CEM450