STATE OF CALIFORNIA • DEPARTMENT OF TRANSPORTATION

RESIDENT ENGINEER'S DAILY REPORT
ASST. RESIDENT ENGINEER'S DAILY REPORT

CEM-4501 (REV. 11/92) CT# 7541-3506-1

☐ RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 45

☒ ASST. RESIDENT ENGINEER'S DAILY REPORT - FILE CAT. 46

JOB STAMP

04-0120F4
04-SF-80-13.2/13.9
SF/OBB EAST SPANS SEISMIC SAFETY PROJECT (SELF ANCHORED SUSPENSION: TOWER AND SUPERSTRUCTURE).

REPORT NO. SFOBB-SAS-0885	DATE 14th June 2010 (M) T W T F S S (Circle Day
SHIFT HOUR: START 0700 STOP 1630	TEMPERATURE MIN MAX
WEATHER	

(1) Review emails & PMW actions

(2) Discuss Goodwin RFI's with K. Baltzer. - Confirmation that Goodwin don't mean Chord length but eliptical length.

(3) Discuss Survey (measuring) of ~~[illegible]~~ Surrender brackets with B. Boal. ABF (A. Reeve) Confirm that they are starting this work @ 0730 note: Request time sheet for A. Reeve.

(4) Discuss relative issues concerning out of tolerance surrender grooves for C/Bonds with Design JV.

(5) Discuss fabrication issue @ WireCo with MEJS. Broken wire repaired when closing of type II rope core. RFI to be issued.

(6) Discuss Extra Work bills with J. Wilcox & B. Boal.

(7) Visit Job site to inspect the measuring of surrender brackets by ABF.

(8) Review Submittal # 830 R02

(9) Inspect Surrender reels for PP 104, 106, 108 & 110. Protective Plastic cover torn, Photos taken to provide to ABF.

SIGNATURE

TITLE
Assistant Structure Representative/ ~~Leadworker~~

'12 JUL 11 AM 9:22 20880

ADA Notice For individuals with sensory disabilities, this document is available in alternate formats. For information call (916) 263-2041 or TDD (916) 263-2044 or write Records and Forms Management, 1120 N Street, Sacramento, CA 95814.

CEM450