

State of California
Department of Transportation
Assistant Resident Engineer's Daily Diary
For: Stanley Ku
Week of 01/21/13-01/25/13
04-0120F4

01/21/2013 Monday
Martin Luther King Day

01/22/2013 Tuesday Fine

DJV recommended power wash epoxy-coated rebar loops, wire brush away foreign materials, and apply epoxy coating. I e-mailed Gary Thomas on the effectiveness of epoxy coating that has been exposing to sunshine, sea water, and weather since the completion of E2/T1 project. I found that rebar loops protection was called for in CCO 18. The protections should be extended beyond corbel ledge.

01/23/2013 Wednesday Rain

I attended senior meeting. Saman showed me pictures of pier T1 with temporary towers and trusses for OBG erection. The pictures shows UHMW caps were on protections. That means the caps might be removed by ABF or its subcontractor.

01/24/2013 Thursday Fine

I attended safety meeting. In the weekly tower meeting with ABF, I gave Dan McNichol two copies of tower punch list as of January 24, 2013 and photos related to items on the list. Aaron showed me response from METS on epoxy-coated rebar loops. Damaged rebar loops might have to be repaired with zinc primer and epoxy coating.

01/25/2013 Friday Fine

I attended pole relocation meeting. Some of the cables on the pole belong to AT&T. AT&T will identify those cables. Those cables might have to be placed in a trench and route to inside IERBYS building. I e-mailed Karen on my comments about 50% specifications and 50% construction plans.


1/28/2013

46.01

2013-JAN-31 025122