

State of California
Department of Transportation
Assistant Resident Engineer's Daily Diary
For: Stanley Ku
Week of 02/25/13-03/01/13
04-0120F4

02/25/2013 Monday Fine

I attended staff meeting. I studied specifications and plans for temporary improvements for IERBYS building.

02/26/2013 Tuesday Fine

Mohammad and I went to Pier T1. I looked at the epoxy-coated reinforcements in the blockout. Since there are openings on the vertical faces and no protection provided to those reinforcements, a lot of reinforcements show signs of corrossions. Uncoated anchors for high strength tensioning rods might be rusted beyond repair.

02/27/2013 Wednesday Fine

I attended internal meeting on ESW. In the meeting, Mohammad expressed his concern that welding shear plates to tower shafts before load testing might introduce stress to the weld because of vertical deformation. The stress might assist in developing planner indication.

02/28/2013 Thursday Fine

I attended safety meeting. I attended coordination meeting for IERBYS building.

03/01/2013 Friday Fine

I studied the 100% draft design for temporary improvements on IERBYS building.



3/14/2013