

State of California
Department of Transportation
Assistant Resident Engineer's Daily Diary
For: Stanley Ku
Week of 04/01/13-04/05/13
04-0120F4

04/01/2013 Monday

Cesar Chavez Day

04/02/2013 Tuesday Fine

I went to tower base to check on final stressing of tower anchor bolts. Side panels for the maintenance new home at waterfront warehouse are not installed.

04/03/2013 Wednesday Rain

I attended general meeting with ABF. Mark MacDonald asked for the status for Dutra's proposal on rebar loop repair work. I told him that I notified DJV. James Duxbury asked for short description of the proposal. I talked to James after the meeting and told him that my goal was to have at least half of the damage rebar loops recoated.

04/04/2013 Thursday Rain

I attended IERBYS building seismic retrofit planning meeting. I attended risk management meeting.

04/05/2013 Friday Fine

I studied Parsons Brinckerhoff's plan to seismic retrofit IERBYS building and e-mailed Mike Whiteside that the reinforcement for the 5" floor slab is #4 at 8" both ways. There is only one layer of reinforcement near the bottom of the slab.



4/17/2013