



**SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 10:43 AM

**Daily Diary Report by Bid Item**

Contract No.: 04-0120F4

Diary #: 119 Const Calendar Day: 307 Date: 12-Jul-2010 Monday

Inspector Name: Travis, Mike Title: Consultant

Inspection Type:

Shift Hours: 06:00 am 03:00 pm Break: Over Time:

Federal ID:

Location:

Reviewer: Lai, Gary Approved Date: Status: Submit

04-0120F4  
04-SF-80-13.2/13.9  
Self-Anchored  
Suspension Bridge

**Weather**

Temperature 7 AM 12 PM 4PM  
Precipitation Condition

Working Day  If no, explain:

**Diary:**

Dispute

**Electrical Submittals**

ABF-SUB-000104R01 - Electrical System Products: Fiber Optic outside Plant Cable - Bleyco Inc.

Reviewed this submittal and found that this submittal should be coordinated with the other contracts due to integration throughout the projects. This item has an issue with the inspection criteria requirements (5X vs. 10X magnification for cracks). Awaiting confirmation from the Caltrans Design source to make a decision.

ABF-SUB-001648R00 Electrical System Equipment: Underground Vaults: Saddle Racks- Bleyco Inc. This equipment was included and specified in the Change Order #110. Sam Patel, PB (Design Group) and coordination with other contracts is being performed for this submittal.

ABF-SUB-001649R00 Electrical System Equipment: 15 kV Splices, Terminations, Related Materials- Bleyco Inc. This equipment was included and specified in the Change Order #110. Sam Patel, PB (Design Group) and coordination with other contracts is being performed for this submittal.

ABF-SUB-001650R00 Electrical System Equipment: Inner duct Details - Bleyco Inc. This equipment was included and specified in the Change Order #110. Sam Patel, PB (Design Group) and coordination with other contracts is being performed for this submittal.

\*\*\*\*\*

**MEP Charts - ZPMC Fabrication**

Ongoing work to maintain an updated data base for the MEP items associated with the Shop Drawings:

- 1) Maintaining the MEP penetration tracking charts for the OBG and Tower Structure.
- 2) Maintaining the MEP attachments tracking charts for the OBG and Tower Structure to be installed during fabrication.
- 3) Reviewing incoming updated submittals and coordinating with PB (Parsons - Electrical Designers). Provide ongoing updates to the tracking charts.

\*\*\*\*\*



---

**Daily Diary Report by Bid Item**

Job Name: 04-0120F4

Inspector Name Travis, Mike

Diary #: 119

Date: 12-Jul-2010

Monday

---

**Shop Drawing Submittal**

**Status Meeting**



Submittal Status Meeting ( Caltrans - Design Group) was held @ 8:30 AM to cover all ongoing shop drawings being review for processing back to the Contractor.

\*\*\*\*\*

