



SAS Superstructure

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 9:56 AM

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 113 Const Calendar Day: 437 Date: 19-Nov-2010 Friday
 Inspector Name: Brignano, Bob Title: Transportation Engineer
 Inspection Type:
 Shift Hours: Break: Over Time:
 Federal ID:
 Location:
 Reviewer: Schmitt, Alex Approved Date: Status: Submit

04-0120F4
 04-SF-80-13.2/13.9
 Self-Anchored
 Suspension Bridge

Weather

Temperature	7 AM	12 PM	4PM
Precipitation			Condition

Working Day If no, explain:

Diary:	Dispute
General Comments	<input type="checkbox"/>
ITEM 52 FURNISH STRUCTURAL STEEL (BRIDGE)(TOWER); ITEM 55 FURNISH STRUCTURAL STEEL (BRIDGE)(BOX GIRDER); HIGH STRENGTH FASTENER ASSEMBLY PRE-INSTALLATION TESTING: For ABF, engineers Chris Bausone and Sabrina Levine are present for testing. For CT, engineer Bob Brignano is present for testing. Today's testing is for rotational capacity, minimum tension verification, and inspection torque. Work happens at Bolt Testing Conex ABF ID 002079 with Skidmore Model HT 4000 ABF ID 000612 in the warehouse. The samples for testing today were taken on a previous date. Testing rocap lots is 1000 to 1130. Five (5) rocap lots of M24 assemblies are tested. See the attached Bolt Test Form for details of the testing. Note this form is combined with test results from yesterday on 11/18/2010.	

