



**SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 9:55 AM

**Daily Diary Report by Bid Item**

Contract No.: 04-0120F4

Diary #: 119 Const Calendar Day: 461 Date: 13-Dec-2010 Monday

Inspector Name: Brignano, Bob Title: Transportation Engineer

Inspection Type:

Shift Hours: Break: Over Time:

Federal ID:

Location:

Reviewer: Schmitt, Alex Approved Date: Status: Submit

04-0120F4  
04-SF-80-13.2/13.9  
Self-Anchored  
Suspension Bridge

**Weather**

Temperature 7 AM 12 PM 4PM

Precipitation Condition

Working Day  If no, explain:

**Diary:**

Dispute

**General Comments**

ITEM 52 FURNISH STRUCTURAL STEEL (BRIDGE)(TOWER);  
ITEM 55 FURNISH STRUCTURAL STEEL (BRIDGE)(BOX GIRDER);  
HIGH STRENGTH FASTENER ASSEMBLY PRE-INSTALLATION TESTING:

For ABF, engineer Chris Bausone is present. For CT, engineer Bob Brignano is present. Today's testing is for inspection torque. Work happens at Bolt Testing Conex ABF ID 002079 in the warehouse with Skidmore Model HT 4000 ABF ID 000612. Testing this rocap lot is 1200 to 1245. One rocap lot (M30, A325M mechanically galvanized) is tested in the Skidmore Model HT 4000 ABF ID 000612 by turning from the bolt head to determine the inspection torque.

See the attached Bolt Test Form for details of the testing.

