



SAS Superstructure

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 9:55 PM

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 420 Const Calendar Day: 190 Date: 11-Dec-2012 Tuesday

Inspector Name: Altamirano, Victor Title: Transportation Engineer

Inspection Type:

Shift Hours: Break: Over Time:

Federal ID:

Location:

Reviewer: Schmitt, Alex Approved Date: Status: Submit

04-0120F4
04-SF-80-13.2/13.9
Self-Anchored
Suspension Bridge

Weather

Temperature 7 AM 50 - 60 12 PM 50 - 60 4PM 50 - 60

Precipitation Condition

Working Day If no, explain:

Diary:

Dispute

Work description.

Inspector: Victor Altamirano (8 hours reg. and 2 hours OT)

Date: 121112

Weather: 58 deg. / Sunny

Field Work

I continued overseeing the cable wrapping of the main cable. Workers were wrapping cable at PP 46 downhill with the pull machine. They applied zinc paste on the PWS wires. Observed workers applying WD 40 and informed them not to. I was concern that the motor WD 40 would get on the zinc paste.

Office work: Worked on diaries.

Workers Names:

- Obra Paulk
James Morris
Carlos Bustamante
Javier Arvizu
Ryan Biskner
Bizmark
Mario Marquez
Ryan Nash

04-0120F4 Bid Item: 067 C-PWS-WCS.067 Wrap Cable System

AMERICAN BRIDGE/FLUOR, A JV

