



SAS Superstructure

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 22-Nov-14

Time 11:05 AM

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 549 Const Calendar Day: 334 Date: 04-May-2013 Saturday

Inspector Name: Wright, Doug Title: Transportation Engineer

Inspection Type: Intermittent

Shift Hours: 07:00 AM 03:30 PM Break: 00:30 Over Time: 08:00

Federal ID:

Location:

Reviewer: Schmitt, Alex Approved Date: Status: Submit

04-0120F4  
04-SF-80-13.2/13.9  
Self-Anchored  
Suspension Bridge

Weather

Temperature 7 AM 12 PM 4PM  
Precipitation Condition

Working Day  If no, explain:

Diary:

Dispute

A354, Grade BD rod Inspection

Today I was doing inspection of A354, Grade BD rods.

- At 07:00, I arrived at the pier-7 office.
- From 07:00 until 07:45, I did misc office work, including writing my diary from yesterday (PMIV was down yesterday afternoon) & checking email.
- At 08:00, I arrived on the bridge.
- From 08:00 until 08:45, I did a walk-through of the bridge to check for any work on the Cable. None was ongoing other than painting.
- From 08:45 until 09:45, Lorraine Woo & I were doing inspection of A354, Grade BD rods at the PWS anchorage of the eastbound bridge. This is the regular inspection done at the request of Bill Casey to verify no rods have broken. No rods were broken or loose.
- From 09:45 until 10:30, Lorraine Woo & I were doing inspection of A354, Grade BD rods at the PWS anchorage of the westbound bridge. No rods were broken or loose.
- From 10:30 until 11:45, Lorraine Woo & I climbed to the top of the Tower to do inspection of A354, Grade BD rods on the Tower booms. No rods were broken or loose.
- From 11:45 until 13:00, Lorraine Woo & I were doing inspection of A354, Grade BD rods on the B14 cable brackets on both the eastbound & westbound bridges. No rods were broken or loose.
- At 13:15, I left the bridge.
- From 13:30 until 14:00, lunch.
- From 14:00 until 15:30, I compiled the sign-off sheets for the A354 rods that we checked today, wrote my diary for the day, & sent my timesheet for the week.

04-0120F4 Bid Item: 067 C-SUS-SCC.067 Install Suspender Clamps, Separators, Collars

AMERICAN BRIDGE/FLUOR, A JV

