Daily Diary Report by Bid Item

Contract No.: **04-0120F4**
Diary #: **225** **Const Calendar Day:** 588 **Date:** **13-Jan-2014** **Monday**
Inspector Name: **Liu, Tai-Lin** **Title:** **Transportation Engineer**
Inspection Type: Continuous
Shift Hours: 04:30 PM 02:30 AM **Break:** 00:30 **Over Time:** 02:00
Federal ID:
Location:
Reviewer: **Awal, Mohammad** **Approved Date:** 18-Jan-14 **Status:** Approved

04-0120F4
04-SF-80-13.2/13.9
Self-Anchored
Suspension Bridge

Weather

Temperature **7 AM** **12 PM** **4PM** 60 - 70
Precipitation **Condition** Clear

Working Day ☑ If no, explain:

Diary: Dispute ☐

Tower Activites

01-13-14, Monday, Night Shift: 4:30 PM – 2:30 AM, Partly Cloudy, 58/39 F

Electro Slag Weld (ESW) - Weld Repair on Tower Base Transversal Indications.

* Arrived at Burma SAS office around 04:30 PM. Saw Robert & Bob at office. Prepared paper work and went to field.

* At field saw boat driver Justin and safety office Gregory (510-509-0502). At the field office, talked to QA-Ed Leach & James (METS) to find the field status.

* QA Bonifacio Daquinag replaced by Salvador Merino with another QC (SE) Patrick Swain were on duty tonight.

* Welder Mike Jimenez (Forman), performed welding on location J3 / Face B.

* Welder Chris Bowles performed welding on W2 / Face A area through the whole shift.

* Brendon Chapman started excavation on N7 / Face B until 09:30 PM. MT was performed by QA (James) / QC (Salvador Merino) at Y = 1430 – 1950 area. Brendon started welding in this area through whole shift.

* Jose Torres was running around helping other welder. Later on, he performed excavation on S / Face B, multiple area through whole shift.

* Reggie Humphrey performed welding on D/ Face A area (Y= 610 - 875 (D7)) through the whole shift.

* Welder Man Chun Ma performed grinding on R / Face B (4 repairs). Later on he started performed welding on this area. Expected to perform MT/MT on Wednesday..

* No UT testing performed this shift.

* See QA's reports (Ed Leach and James Doe) for welder's detailed activities.

* QC Salvador Merino & Patrick Swain worked 8 regular and 2 OT hours this shift, respectively.

04-0120F4 **Bid Item:** **053** **T-L01-DSE.053** **Tower Lift 01 Diaphram Tower SE Erect structural steel (bridge tower)**
AMERICAN BRIDGE/FLUOR, A JV

Labor

Daily Diary Report by Bid Item

Job Name: 04-0120F4 **Inspector Name:** Liu, Tai-Lin **Diary #:** 225 **Date:** 13-Jan-2014 Monday

Trade	Class	Name	RT Hrs	OT Hrs	DT Hrs	Total	Remarks	Dispute
Contractor: AMERICAN BRIDGE/FLUOR, A JV								
Safety Coordinator	OTH	GREG ANDERSON	8.00	2.00	0.00	10.00		☐
Operator	JNM	JUSTIN GARRETT	8.00	2.00	0.00	10.00		☐
Welder	APP	Reggie Humphry	8.00	2.00	0.00	10.00		☐
Ironworker	JNM	BRENDON CHAPMAN	8.00	2.00	0.00	10.00		☐
Ironworker	JNM	MAN CHUN MA	8.00	2.00	0.00	10.00		☐
Ironworker	APP	JOSE TORRES	8.00	2.00	0.00	10.00		☐
Ironworker	JNM	CHRISTOPHER BOWLES	8.00	2.00	0.00	10.00		☐
Ironworker	JNM	DONALD PLUMB	0.00	0.00	0.00	0.00		☐
Ironworker	JNM	MICHAEL JIMENEZ	8.00	2.00	0.00	10.00		☐

Equipment

Equipment ID	Description	RT Hrs	OT Hrs	ST Hrs	IT Hrs	Rental Company Remarks	Dispute
Contractor: AMERICAN BRIDGE/FLUOR, A JV							
*E0020562	WELDING EQUIPMENT					No	
		8.00	2.00	0.00	0.00		☐
*E0030562	WELDING EQUIPMENT					No	
		8.00	2.00	0.00	0.00		☐
*E0010562	WELDING EQUIPMENT					No	
		8.00	2.00	0.00	0.00		☐
2292	WELDER, 600 AMP					No	
		8.00	2.00	0.00	0.00		☐
2293	WELDER, 600 AMP					No	
		8.00	2.00	0.00	0.00		☐

Attachment

Preheat at W2/Face A area, Chris perform welding later on

Mike performed welding at J3 / Face B area

Daily Diary Report by Bid Item

Job Name: 04-0120F4 **Inspector Name:** Liu, Tai-Lin **Diary #:** 225 **Date:** 13-Jan-2014 Monday

Welding at D7 area

Location N7 / Face B - Excavation & MT