



**Daily Diary Report by Bid Item**

Contract No.: 04-0120F4

Diary #: 635 Const Calendar Day: 855 Date: 07-Oct-2014 Tuesday  
 Inspector Name: Feather, Bernard Title: Transportation Engineer  
 Inspection Type: Intermittent  
 Shift Hours: 08:00 am 05:00 pm Break: 01:00 Over Time:  
 Federal ID:  
 Location:  
 Reviewer: Shedd, Bill Approved Date: Status: Submit

04-0120F4  
 04-SF-80-13.2/13.9  
 Self-Anchored  
 Suspension Bridge

**Weather**

Temperature 7 AM 12 PM 4PM  
 Precipitation Condition clear, warm

Working Day  If no, explain:

**Diary:** Dispute  
**General Comments**  
 MEP staff meeting 0830-0900. FWS field work is complete with the exception of minor punchlist items. Inspection of the labeling of the piping along the IB barrier of the EB bridge. Misc MEP paperwork and write diaries.

04-0120F4 Bid Item: 125 0-000-000.125 DOMESTIC WATER (2 1/2 NPS)  
 F.W. SPENCER AND SON, INC

**Diary:** Dispute  
**Bike Path Piping** 125 0-000-000.125  
 RFI 3699 for the fabrication of the additional PS-3 slider plate and clamp pipe support, to replace the ones missing between PP 118 and 120 along the bike path, was unofficially approved. ABF had already fabricated the support based on discussions about the draft shop drawing, and was given direction to proceed with the blasting and priming of the support in preparation of painting.

04-0120F4 Bid Item: 128 0-000-000.128 DEHUMIDIFIER SYSTEM  
 F.W. SPENCER AND SON, INC

**Diary:** Dispute  
**Dehumidification System** 128 0-000-000.128  
 Bill O'Sullivan was informed that the Department needed an electronic copy of the Dehumidification System maintenance manual (final Submittal 2916) as well as three hard copies of the manual, one for the SCADA operators, and two for the CT Maintenance file.

CCO-384 Bid Item: 001 0-BAR-EFA.384 Paint Repair Behind Barrier Rail  
 CERTIFIED COATINGS COMPANY

**Diary:** Dispute  
**Painting Pipe** 001 0-BAR-EFA.384  
 I inspected the labeling of the mechanical piping along the IB barriers of the EB and WB bridges. Everything looked good and I sent an email to Scott Yeager, ABF, that it is bought off. I did note,

---

## *Daily Diary Report by Bid Item*

**Job Name:** 04-0120F4    **Inspector Name** Feather, Bernard    **Diary #:** 635    **Date:** 07-Oct-2014    **Tuesday**

---

however, that the labeling of the piping at the base of W2E and W2W have not been done. Scott was informed that those need be labeled as well.