

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
 690 Walnut Ave. St. 150
 Vallejo, CA 94592-1133
 (707) 649-5453
 (707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.12**DAILY PROJECT JOURNAL****Prime Contractor:** American Bridge/Fluor Enterprises, a JV**Report No:** DPJ-000316**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Dated:** 20-Sep-2007**Location:** Pudong Office, Shanghai, China**Submittals(New / Total):****CWR's:** 0 / 4**HSR's:** 0 / 2**NCR's:** 0 / 4

Item	Title	Detail
1	Key conversations	Mr. Craig Knops of ABF had previously requested that METS look into why the request to use THY-55 wire (ABF-RFI-803) was rejected by the Department. After discussing this with the METS team at Pier 7, it was noted that the ABF WQCM, Mr. Jim Bowers, had requested to reject the use of this wire as it did not appear to be an all-position electrode and the supporting data sheets did not have enough information to prove otherwise. METS will forward these comments to ABF.
2	Logistics	Due to Typhoon Wipha, ferry boats were still on hold until approximately 1500 hours this afternoon. Thus, no one from Caltrans Team China went to Changxing Island until after 1500 hours today.

Inspected By: Smith, Ryan

Quality Assurance Inspector

Reviewed By: Wahbeh, Mazen

QA Reviewer