

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-000058**Date Inspected:** 11-Jan-2007**Project Name:** SAS Superstructure**OSM Arrival Time:** 800**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1700**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Huang Wei**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Bid 52, 55 Tower and Girder**Summary of Items Observed:**

Office of Structural Materials Quality Assurance Inspector (QA), Mark Wright was present as requested to observe quality control functions related to procedure qualification record (PQR) testing at the ZPMC facility in Shanghai, China for the San Francisco Oakland Bay Self Anchored Suspension Bridge.

The Caltrans Quality Assurance (QA) Inspector was present as requested to witness the welding of a Procedure Qualification (PQR) Figure 5.8 fillet test plate HP2006139 using Submerged Arc Welding (SAW), using F7A3-EM12K 4.8mm electrode, in the 1F (flat) position. The material used was 26mm thick A709-50-2 for both plates. The welding was performed per the AWS D1.5, Section 5.10.3 requirements. The welding appeared to comply with the contract documents.

See TL-6032s for details of this test.

Summary of Conversations:

See Task Leader journal for this date.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Mazen Wahbeh, (818) 292-0659, who represents the Office of Structural Materials for your project.

Inspected By: Wright, Mark

Quality Assurance Inspector

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

Reviewed By: McClary, David

QA Reviewer