

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-000082**Date Inspected:** 10-Feb-2007**Project Name:** SAS Superstructure**OSM Arrival Time:** 1200**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1700**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Zhou Daqing**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** welder Qualifications**Summary of Items Observed:**

Office of Structural Materials Quality Assurance Inspector (QA), Mark Wright was present as requested to observe quality control functions related to procedure qualification record (PQR) testing at the ZPMC facility in Shanghai, China for the San Francisco Oakland Bay Self Anchored Suspension Bridge.

The Caltrans Quality Assurance (QA) Inspector was present to observe the welder qualifications being conducted at ZPMC. The QA observed that Moody International was conducting the Certified Welding Inspector (CWI) functions. The QA also observed that the 6 welders being tested were running out of parameters of the posted welding procedure specifications (WPS). The travel speed was too low for the WPS specified speed. The welders also performed a wide weave weld cap which was measured to be outside of the size stated in the code book. As shown in the photo below.

WELDING INSPECTION REPORT

(Continued Page 2 of 2)



Summary of Conversations:

See Task Leader journal for this date.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Mazen Wahbeh, (818) 292-0659, who represents the Office of Structural Materials for your project.

Inspected By:	Wright,Mark	Quality Assurance Inspector
Reviewed By:	McClary,David	QA Reviewer
