

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-006840**Date Inspected:** 17-May-2009**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Li Yang**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG crossbeams and superstructure trial asse**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance Inspector (QA) Steve Hall was present during the times noted above for observations relative to the fabrication of the SAS Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island, in Shanghai, China. QA observed and/or found the following:

OBG cross beam CB4

This QA completed the documentation of segment green tag Non Destructive Testing (NDT) performed by Caltrans QA on the above mentioned crossbeam. Documentation accounted for all of the Ultrasonic Testing (UT) and Magnetic particle Testing (MT) performed on each segment weld. The document has been stored on the Caltrans (CT) server under team OBG // segment green tags // CB4.

OBG cross beam CB5

No significant work was observed on the above mentioned crossbeam during the time this QA was present.

OBG cross beam CB6

No significant work was observed on the above mentioned crossbeam during the time this QA was present.



OBG segment 5BW

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

During random Visual Testing (VT) of the above mentioned OBG segment this QA observed the end of a horizontal Floorbeam web stiffener was bent downward. This stiffener is located on the inboard side of floorbeam sub assembly identified as FL3 at PP034. The stiffener in question is the fifth stiffener from the bottom flange of the FL3 floorbeam. See photos for details. This QA notified ZPMC QA inspector identified as Mr. Wang Lu of this issue. Mr. Wang informed this QA that ZPMC would prepare and submit to the Engineer a repair procedure to correct this deficiency.

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.



Summary of Conversations:

As mentioned above.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang (15000422372), who represents the Office of Structural Materials for your project.

Inspected By:	Hall,Steven	Quality Assurance Inspector
----------------------	-------------	-----------------------------

Reviewed By:	Prue,Erik	QA Reviewer
---------------------	-----------	-------------