

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-008941**Date Inspected:** 14-Sep-2009**Project Name:** SAS Superstructure**OSM Arrival Time:** 645**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1845**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Li zhi jiang**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG**Summary of Items Observed:**

On this date Caltrans OSM Quality Assurance (QA) Inspector, D.Sukanthan was present during the time noted above for observations relative to the work being performed.

OBG # CROSS BEAM 06

This QA inspector performed Magnetic Particle Test of approximately 15% of the area previously tested and accepted by ZPMC Quality Control Personnel. This QA Inspector generated an Magnetic Particle Test report for this date. The member is identified as Side plate / Bottom Plate / Deck plate. The weld designations reviewed are as follows:

(CB202A-006-020)

(CB202A-006-011)

(CB202A-006-019)

(CB202A-006-008)

(CB202A-006-011)

(CB202G-009-147)

(CB202G-009-165)

(CB202G-009-148)

(CB202G-009-166)

(CB202G-010-147)

(CB202G-010-165)

WELDING INSPECTION REPORT

(Continued Page 2 of 3)

(CB202G-010-148)
(CB202G-010-166)
(CB202G-011-147)
(CB202G-011-165)
(CB202G-011-148)
(CB202G-011-166)
(CB202G-012-147)
(CB202G-012-165)
(CB202G-012-148)
(CB202G-012-166)

This QA Inspector randomly observed the following work in progress:

OBG # BAY 01

Flux Cored Arc Welding Process:

Welding of weld joint –002,003 located on PCMK CW002B-PP104. Welder is identified as 251246. ZPMC QC is identified as Tian Lei. The welding variables recorded by QC appeared to comply with the WPS-B-T-2232-TC-U4b-F-1.

Welding of weld joint –001 located on PCMK CW001A-PP068. Welder is identified as 219189. ZPMC QC is identified as Tian Lei. The welding variables recorded by QC appeared to comply with the WPS-B-T-2232-TC-U4b-F-1 / WPS-B-T-2132-3.

Submerged Arc Welding Process:

Welding of weld joint –003,004 located on PCMK CB202B-015. Welder is identified as 215548. ZPMC QC is identified as Tian Lei. The welding variables recorded by QC appeared to comply with the WPS-B-T-2221-B-L2C-S-2.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.

Summary of Conversations:

No Relevant Conversation

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang 150-00422372, who represents the Office of Structural Materials for your project.

Inspected By: Sukanthan,Dhanasingh

Quality Assurance Inspector

WELDING INSPECTION REPORT

(Continued Page 3 of 3)

Reviewed By: Prue,Erik

QA Reviewer