

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-011391**Date Inspected:** 08-Jan-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Liu Hua Jie**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** OBG**Summary of Items Observed:**

On this day CALTRANS OSM Quality Assurance Inspector (QA) Shailesh Wadkar was present during the times noted above for observations relative to the fabrication of the Self Anchored Suspension (SAS) Superstructure being performed by Zhenhua Port Machinery Company (ZPMC) at Changxing Island, in Shanghai, China. QA observed and/or found the following:

Bay 14:

This QA Inspector observed the following work in progress:

Flux Cored Arc Welding (FCAW) of weld joint CA094-003 (for 11EE). Welders are identified as 050242 & 044779. ZPMC Quality Control (QC) is identified as Zhong Guo Hui. The welding variables recorded by QC appeared to comply with the Applicable WPS: WPS-B-T-2232-TC-U4B-F.

FCAW of weld joint CSD2-PP108.5-081 & 082 (for 11EE). Welder is identified as 050988. ZPMC Quality Control (QC) is identified as Zhong Guo Hui. The welding variables recorded by QC appeared to comply with the Applicable WPS: WPS-B-T-2133.

FCAW of weld joint SEG3004L-014 & 019 (for 12AW). Welder is identified as 202122. ZPMC Quality Control (QC) is identified as Xu Tau. The welding variables recorded by QC appeared to comply with the Applicable WPS: WPS-B-T-2231-B-U2-F.

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

FCAW of weld joint SEG071A-025 & 022 (for 11DW). Welder is identified as 202122. ZPMC Quality Control (QC) is identified as Xu Tau. The welding variables recorded by QC appeared to comply with the Applicable WPS: WPS-B-T-2231-B-U2-F.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.

Summary of Conversations:

Only general conversation was held between QA and QC concerning this project.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang - 15000422372., who represents the Office of Structural Materials for your project.

Inspected By:	Wadkar,Sailesh	Quality Assurance Inspector
Reviewed By:	Hall,Steven	QA Reviewer
